## National Load Despatch Centre Total Transfer Capability for November 2015

Issue Date: 1	/11/2015		Issu	e Time: 210	00 hrs			Revision	No. 6
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st Nov 2015 to 30th Nov 2015	00-24	2500	500	2000	706	1294		
	1st Nov 2015	00-24	7750	500	7250	5938	1312		
	2nd Nov 2015 to	00-09	7450	500	6950	5818	1132		Revised due to shutdown of
WR-NR*	3rd Nov 2015 4th Nov 2015 to	09-24'	6950		6450	5818	632	-500	765/400 kV Phagi ICT-1
	30th Nov 2015 to	00-24	7450	500	6950	5818	1132		
		00-06	2000		1800	293	1507		
NR-ER*	1st Nov 2015 to	06-18'	2000	200	1800	358	1442		•
	30th Nov 2015	18-24	2000	<u> </u>	1800	293	1507		
ER-NR*	1st Nov 2015 to 30th Nov 2015	00-24	3400	300	3100	2431	669		
	1st Nov 2015 to					No limit i	s being specified.		
W3-ER <sup>\$</sup>	30th Nov 2015 to	00-24					allowed via W3-E	R-NR.	
ED W2	1st Nov 2015 to	00.24					s being specified.		
ER-W3	30th Nov 2015	00-24				NO IIIIII I	s being specified.		
WR-SR	1st Nov 2015 to 30th Nov 2015	00-24	3000	750	2250	2250	0		
SR-WR *	1st Nov 2015 to 30th Nov 2015	00-24				No limit is	s being Specified.		
		00-06						[	
	1st Nov 2015	18-24	2650	0	2650	2585	65		
		06-18'				2650	0		
	2nd Nov 2015 to	00-06	2650		2650	2585	0		-
ER-SR	3th Nov 2015	06-18' 18-24	2350 2350	0	2350 2350	2650 2585	0 0	-	
		00-06	2550		2550				
	4th Nov 2015 to 30th Nov 2015	18-24	2650	0	2650	2585	65		
		06-18'				2650	0		
SR-ER *	1st Nov 2015 to 30th Nov 2015	00-24				No limit is	s being Specified.		
		00-17							
ER-NER	1st Nov 2015 to	23-24	1310	45	1265	210	1055		
	30th Nov 2015	17-23	1100		1055		845		
NER-ER	1st Nov 2015 to 30th Nov 2015	00-17 23-24	1420	45	1375	0	1375		
	3001100 2015	17-23	1370	45	1325		1325		
W3 zone	1st Nov 2015 to		No limit is b	eing specified	(in case of ske	wed inter-regional	flows or any const	traints appe	aring in the system, W3 zone export
								-rpe	o in the second of the second
Injection	30th Nov 2015	00-24	would be rev	ised according	gly)				

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

### National Load Despatch Centre Total Transfer Capability for November 2015

Issue Date: 1/11/2015 Issue Time: 2100 hrs						Revision	No. 6			
	Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments

\$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.

1) S1 comprises of Telangana, AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Puducherry

2) W3 comprises of the following regional entities :

a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n) Vandana Vidyut

# The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

1) The TTC value will be revised to normal values after restoration of shutdown.

2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

#### Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2.High Loading of 400kV Singrauli-Anpara S/C.
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	1. n-1 contingency of one cicuit of 400 kV Biharshariff- Lakhisarai leads to high loading on the other cicuit 2. n-1 contingency of one circuit of 400 kV Farakka-Malda leads to high loading of the other circuit
WR-SR & ER-SR	(n-1) contingency of one circuit of 765 kV Raichur - Sholapur will lead to 2000 MW loading on the other circuit Low Voltage at Gazuwaka (East) Bus.
ER-NER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa. n-1 cntingency of 400/132 kV, 2 x 200 MVA ICTs at Silchar
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
W3 zone Injection	

### Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
		00-05	11000		10200		1831		
		05-08'	111000		10200		1931		
	1st Nov 2015	08-19'	11000	800	10200	8369	1831		
		19-24	10250		9450		1081		
		00-05	10650		9850		1481		
		05-08'	11150		10350		1981		
	2nd Nov 2015 to 3rd Nov 2015	08-09'	10650	800	9850	8369	1481		Revised due to shutdown of 765/400 kV Phagi ICT-1
NR*	514 1407 2015	09-19'	9935		9135		766	-715	
		19-24	9282		8482		113	-668	
	4th Nov 2015 to 30th Nov 2015	00-05	10650	800	9850	8369	1481		
		05-08'	11150		10350		1981		
		08-19'	10650		9850		1481		
		19-24	9950		9150		781		
NER	1st Nov 2015 to 30th Nov 2015	00-17 23-24	1310	45	1265	210	1055		
	3001100 2013	17-23	1100		1055		845		
WR									
		00-06	5650		4900	4835	65		
	1st Nov 2015	06-18'	5650	750	4900	4900	0		
		18-24	5650		4900	4835	65		
		00-06	5650		4900	4835	65		
SR	2nd Nov 2015 to	06-18'	5350	750	4600	4900	0		
SK	3rd Nov 2015	18-24	5350		4600	4835	0		
		00-06	5650		4900	4835	65		
	4th Nov 2015 to	06-18'	5650	750	4900	4900	0		
	30th Nov 2015	18-24	5650		4900	4835	65		
* Fifty Per	cent (50 % ) Count			count of LTA				would be co	onsidered for advanced

transactions (Bilateral & First Come First Serve).

\* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NR ATC = C

Margin for WR-NR applicants = B \* A/(B+C) Margin for ER-NR Applicants = C \* A/(B+C)

Example: Margin for WR-NR applicants from 00-05 hours = 231 \* 5900/(5900+3100) = 151 Margin for ER-NR applicants from 00-05 hours = 231 \* 4500/(5900+3100) = 80

## Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st Nov 2015 to	00-06 06-18'	4500	700	3800 3800	999 1064	2801 2736		
	30th Nov 2015	18-24	4500		3800	999	2801		
NER	1st Nov 2015 to	00-17 23-24	1420	45	1375	0	1375		
	30th Nov 2015	17-23	1370	45	1325		1325		
WR									
SR *	1st Nov 2015 to 30th Nov 2015	00-24		No limit is being Specified.					

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

## Limiting Constraints

		(n-1) contingency of 400 kV Biharshariff- Lakhisarai S/C					
	Import	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit.					
NR		2.High Loading of 400kV Singrauli-Anpara S/C.					
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.					
	Export	(n-1) contingency of 400 kV Saranath-Pusauli					
	<b>.</b> .	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA					
NER	Import	ICT at Misa. n-1 cntingency of 400/132 kV, 2 x 200 MVA ICTs at Silchar					
	E4	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA					
	Export	ICT at Misa.					
SR	Import	(n-1) contingency of one circuit of 765 kV Raichur - Sholapur will lead to 2000 MW loading on the other circuit					
SK	Import	Low Voltage at Gazuwaka (East) Bus.					

# National Load Despatch Centre Total Transfer Capability for November 2015

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	26/08/2015	Whole Month	Revised due to commissioning of 765kV Gwalior Ckt-1&2, 765kV Phagi-Bhiwani S/C and STOA margin revised due to operationalization of MTOA.	WR-NR/ Import of NR
		Month	STOA Margin revised due to Operationalization of LTA.	W3 Zone Injection
2	09-02-2015	Whole Month	A remark has been put on Simultaneous Import of NR for approving STOA Bilateral Transactions	Import of NR
3	24/9/2015	Whole	Revised due to revision in 765kV Gwalior-Agra Ckt-1&2 SPS setting.	WR-NR/ Import of NR
		Month	Revised due to commissioning of 765kV Dharamjaigarh- Jabalpur D/C.	W3 Zone Injection
			STOA margin revised due to operationalization of MTOA.	WR-NR/ Import of NR
	15/10/2015	Whole Month	Revised due to commissioning of 765kV Dharamjaigarh- Jabalpur D/C.	ER-W3
4			Revised due to commissioning of 765 kV Aurangabad - Sholapur D/C	WR- SR/Import of SR
			Revised due commissioning of 765 kV Aurangabad-Sholapur D/C, 765 kV Dharamjaigarh - Jabalpur D/C and considering the present inter regional power flow pattern	W3 Zone Injection
5	01-11-2015	Whole month	Revised due to outage of Vindhyachal BTB HVDC Block-1 and STOA margin revised after an inadvertent error in LTA/MTOA summation figure is fixed	WR-NR/ Import of NR
		2/11/2015 to 3/11/2015	Revised due to shutdown of 400 kV Rengali-Indravati S/C	ER- SR/Import of SR
6	01-11-2015	2/11/2015 to 3/11/2015	Revised due to shutdown of 765/400 kV Phagi ICT-1	WR-NR/ Import of NR

AS	SUMPTIONS IN BASECASE					
				Month : November '15		
S.No.	Name of State/Area		Load	Generation		
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)	
I	NORTHERN REGION					
1	Punjab	5559	3491	2152	2085	
2	Haryana	6228	2948	2217	2217	
3	Rajasthan	9325	8655	5570	5514	
4	Delhi	3175	1549	790	790	
5	Uttar Pradesh	12198	11682	5569	5587	
6	Uttarakhand	1679	1218	525	228	
7	Himachal Pradesh	1376	925	336	263	
8	Jammu & Kashmir	2339	2352	401	255	
9	Chandigarh	172	75	0	0	
10	ISGS/IPPs	0	0	19083	11552	
	Total NR	42053	32894	36643	28491	
	EASTERN REGION					
1	Bihar	2831	2132	180	120	
2	Jharkhand	1049	914	540	360	
3	Damodar Valley Corporation	2517	2132	3660	2748	
4	Orissa	3672	2946	3365	1842	
5	West Bengal	6333	5916	4695	3051	
6	Sikkim	125	102	0	0	
7	Bhutan	0	0	0	0	
8	ISGS/IPPs	609	559	10625	9607	
	Total ER	17137	14700	23065	17728	
	WESTERN REGION					
1	Maharashtra	20822	13093	14523	7312	
2	Gujarat	13593	9878	10498	7289	
3	Madhya Pradesh	9763	6885	4479	3426	
4	Chattisgarh	3676	2005	2743	1102	
5	Daman and Diu	306	229	0	0	
6	Dadra and Nagar Haveli	783	562	0	0	
7	Goa-WR	511	288	0	0	
8	ISGS/IPPs	982	973	27229	23303	
	Total WR	50436	33913	59472	42431	

IV	SOUTHERN REGION				
1	Andhra Pradesh	5629	5313	4759	4284
2	Telangana	6366	6065	2427	1899
3	Karnataka	7697	5550	6984	5307
4	Tamil Nadu	11912	11319	6646	5746
5	Kerala	3445	2132	1796	826
6	Pondy	336	220	0	0
7	Goa-SR	85	85	0	0
8	ISGS/IPPs	0	0	10043	9773
	Total SR	35470	30684	32655	27835
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	94	40	0	0
2	Assam	954	698	267	198
3	Manipur	103	56	0	0
4	Meghalaya	301	179	155	87
5	Mizoram	69	41	4	4
6	Nagaland	82	63	8	6
7	Tripura	224	131	106	106
8	ISGS/IPPs	7	7	1303	847
	Total NER	1834	1215	1843	1248
	Total All India	146930	113407	153679	117734