

| National Load Despatch Centre Total Transfer Capability for Nov 2023 | | | | | | | | | |
|---|------------------|------------------|--------------------------------|------------------------|------------------------------------|---|---|----------------------------------|---------|
| Issue Date:Jul 28 2023 | | | | Issue Time:18:29:47 | | | Revision No :1 | | |
| Corridor | Date | Time Period(hrs) | Total Transfer Capability(TTC) | Reliability Margin(RM) | Available Transfer Capability(ATC) | Long Term Access(LTA)/Medium Term Open Access(MTOA) | Margin Available For Short Term Open Access(STOA) | Chnages w.r.t. Previous Revision | Comment |
| ER-NER | 01 Nov to 30 Nov | 00:00 to 07:00 | 1200 | 60 | 1140 | 460 | 680 | 0 | |
| | | 07:00 to 12:00 | 1080 | 60 | 1020 | 460 | 560 | 0 | |
| | | 12:00 to 18:00 | 1000 | 60 | 940 | 460 | 480 | 0 | |
| | | 18:00 to 22:00 | 800 | 60 | 740 | 460 | 280 | 0 | |
| | | 22:00 to 24:00 | 1200 | 60 | 1140 | 460 | 680 | 0 | |
| ER-NR | 01 Nov to 30 Nov | 00:00 to 24:00 | 8000 | 400 | 7600 | 5097 | 2503 | 0 | |
| ER-SR | 01 Nov to 30 Nov | 00:00 to 06:00 | 5700 | 350 | 5350 | 3078 | 2272 | 0 | |
| | | 06:00 to 18:00 | 5700 | 350 | 5350 | 3143 | 2207 | 0 | |
| | | 18:00 to 24:00 | 5700 | 350 | 5350 | 3078 | 2272 | 0 | |
| ER-W3 | 01 Nov to 30 Nov | 00:00 to 24:00 | No limit is being specified. | | | | | | |
| ER-WR | 01 Nov to 30 Nov | 00:00 to 24:00 | NA | NA | | NA | | 0 | |
| NER-ER | 01 Nov to 30 Nov | 00:00 to 07:00 | 3480 | 60 | 3420 | 116 | 3304 | 0 | |
| | | 07:00 to 12:00 | 3480 | 60 | 3420 | 116 | 3304 | 0 | |
| | | 12:00 to 18:00 | 3480 | 60 | 3420 | 116 | 3304 | 0 | |
| | | 18:00 to 22:00 | 3480 | 60 | 3420 | 116 | 3304 | 0 | |
| | | 22:00 to 24:00 | 3480 | 60 | 3420 | 116 | 3304 | 0 | |
| NR-ER | 01 Nov to 30 Nov | 00:00 to 06:00 | 4000 | 300 | 3700 | 125 | 3575 | 0 | |
| | | 06:00 to 18:00 | 4000 | 300 | 3700 | 1990 | 1710 | 0 | |
| | | 18:00 to 24:00 | 4000 | 300 | 3700 | 125 | 3575 | 0 | |
| NR-WR | 01 Nov | 00:00 to 06:00 | 4000 | 500 | 3500 | 1547 | 1953 | 0 | |

| Corridor | Date | Time Period(hrs) | Total Transfer Capability(TTC) | Reliability Margin(RM) | Available Transfer Capability(ATC) | Long Term Access(LTA)/Medium Term Open Access(MTOA) | Margin Available For Short Term Open Access(STOA) | Chnages w.r.t. Previous Revision | Comment |
|--------------|------------------|------------------|--------------------------------|------------------------|------------------------------------|---|---|----------------------------------|---------|
| | to 30 Nov | 06:00 to 18:00 | 4000 | 500 | 3500 | 6089 | 0 | 0 | |
| | | 18:00 to 24:00 | 4000 | 500 | 3500 | 1547 | 1953 | 0 | |
| SR-ER | 01 Nov to 30 Nov | 00:00 to 24:00 | No limit is being specified. | | | | | | |
| SR-WR | 01 Nov to 30 Nov | 00:00 to 06:00 | 7400 | 650 | 6750 | 650 | 6100 | 0 | |
| | | 06:00 to 18:00 | 7400 | 650 | 6750 | 850 | 5900 | 0 | |
| | | 18:00 to 24:00 | 7400 | 650 | 6750 | 650 | 6100 | 0 | |
| W3 Injection | 01 Nov to 30 Nov | 00:00 to 24:00 | NA | NA | | NA | | 0 | |
| W3-ER | 01 Nov to 30 Nov | 00:00 to 24:00 | No limit is being specified. | | | | | | |
| WR-ER | 01 Nov to 30 Nov | 00:00 to 06:00 | 5500 | 300 | 5200 | 990 | 4210 | 0 | |
| | | 06:00 to 18:00 | 5500 | 300 | 5200 | 1040 | 4160 | 0 | |
| | | 18:00 to 24:00 | 5500 | 300 | 5200 | 990 | 4210 | 0 | |
| WR-NR | 01 Nov to 30 Nov | 00:00 to 06:00 | 17800 | 1000 | 16800 | 11451 | 5349 | 0 | |
| | | 06:00 to 18:00 | 17800 | 1000 | 16800 | 11775 | 5025 | 0 | |
| | | 18:00 to 24:00 | 17800 | 1000 | 16800 | 11451 | 5349 | 0 | |
| WR-SR | 01 Nov to 30 Nov | 00:00 to 06:00 | 11600 | 650 | 10950 | 3738 | 7212 | 0 | |
| | | 06:00 to 18:00 | 11600 | 650 | 10950 | 4840 | 6110 | 0 | |
| | | 18:00 to 24:00 | 11600 | 650 | 10950 | 3738 | 7212 | 0 | |

- Based on the actual distribution of corridor flows, Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala 2) W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, l)DB Power, m) KWPCCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

- The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

Simultaneous Import Capability

| Corridor | Date | Time Period(hrs) | Total Transfer Capability(TTC) | Reliability Margin(RM) | Available Transfer Capability(ATC) | Long Term Access(LTA)/Medium Term Open Access(MTOA) | Margin Available For Short Term Open Access(STOA) | Chnages w.r.t. Previous Revision | Comment |
|----------|------------------|------------------|--------------------------------|------------------------|------------------------------------|---|---|----------------------------------|---------|
| ER | 01 Nov to 30 Nov | 00:00 to 24:00 | NA | NA | | NA | | 0 | |
| NER | 01 Nov to 30 Nov | 00:00 to 07:00 | 1200 | 60 | 1140 | 460 | 680 | 0 | |
| | | 07:00 to 12:00 | 1080 | 60 | 1020 | 460 | 560 | 0 | |
| | | 12:00 to 18:00 | 1000 | 60 | 940 | 460 | 480 | 0 | |
| | | 18:00 to 22:00 | 800 | 60 | 740 | 460 | 280 | 0 | |
| | | 22:00 to 24:00 | 1200 | 60 | 1140 | 460 | 680 | 0 | |
| NR | 01 Nov to 30 Nov | 00:00 to 06:00 | 25800 | 1400 | 24400 | 16548 | 7852 | 0 | |
| | | 06:00 to 18:00 | 25800 | 1400 | 24400 | 16872 | 7528 | 0 | |
| | | 18:00 to 24:00 | 25800 | 1400 | 24400 | 16548 | 7852 | 0 | |
| SR | 01 Nov to 30 Nov | 00:00 to 06:00 | 17300 | 1000 | 16300 | 6816 | 9484 | 0 | |
| | | 06:00 to 18:00 | 17300 | 1000 | 16300 | 7983 | 8317 | 0 | |
| | | 18:00 to 24:00 | 17300 | 1000 | 16300 | 6816 | 9484 | 0 | |
| WR | 01 Nov to 30 Nov | 00:00 to 24:00 | NA | NA | | | 0 | 0 | |

- Based on the actual distribution of corridor flows, Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala 2) W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II,

c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, l) DB Power, m) KWPCCL, n) Vandana Vidyut o) RKM, p) GMR Raikheda, q) Ind Barath and any other regional entity generator in Chhattisgarh

- The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

Simultaneous Export Capability

| Corridor | Date | Time Period(hrs) | Total Transfer Capability(TTC) | Reliability Margin(RM) | Available Transfer Capability(ATC) | Long Term Access(LTA)/Medium Term Open Access(MTOA) | Margin Available For Short Term Open Access(STOA) | Chnages w.r.t. Previous Revision | Comment |
|----------|------------------|------------------|--------------------------------|------------------------|------------------------------------|---|---|----------------------------------|---------|
| ER | 01 Nov to 30 Nov | 00:00 to 24:00 | NA | NA | | NA | | 0 | |
| NER | 01 Nov to 30 Nov | 00:00 to 07:00 | 3480 | 60 | 3420 | 116 | 3304 | 0 | |
| | | 07:00 to 12:00 | 3480 | 60 | 3420 | 116 | 3304 | 0 | |
| | | 12:00 to 18:00 | 3480 | 60 | 3420 | 116 | 3304 | 0 | |
| | | 18:00 to 22:00 | 3480 | 60 | 3420 | 116 | 3304 | 0 | |
| | | 22:00 to 24:00 | 3480 | 60 | 3420 | 116 | 3304 | 0 | |
| NR | 01 Nov to 30 Nov | 00:00 to 06:00 | 4000 | 500 | 3500 | 1672 | 1828 | 0 | |
| | | 06:00 to 18:00 | 4000 | 500 | 3500 | 8079 | 0 | 0 | |
| | | 18:00 to 24:00 | 4000 | 500 | 3500 | 1672 | 1828 | 0 | |
| SR | 01 Nov to 30 Nov | 00:00 to 06:00 | 6350 | 650 | 5700 | 2018 | 3682 | 0 | |
| | | 06:00 to 18:00 | 6350 | 650 | 5700 | 2369 | 3331 | 0 | |
| | | 18:00 to 24:00 | 6350 | 650 | 5700 | 2018 | 3682 | 0 | |
| WR | 01 Nov to 30 Nov | 00:00 to 24:00 | NA | NA | | NA | | 0 | |

- Based on the actual distribution of corridor flows, Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala 2) W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II,

c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, l) DB Power, m) KWPC, n) Vandana Vidyut o) RKM, p) GMR Raikheda, q) Ind Barath and any other regional entity generator in Chhattisgarh

- The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

Limiting Constraints

| Corridor | Constraints | Revisions |
|----------|-------------|-----------|
|----------|-------------|-----------|

Revision Summary

| Revision | Date Of Revision | Period Of Revision | Reason for Revision/Comment | Corridor Affected |
|----------|------------------|--------------------|-----------------------------|-------------------|
|----------|------------------|--------------------|-----------------------------|-------------------|

| BASECASE LGBR | | | | | |
|---------------|----------------------------|----------------|--------------------|-----------|---------------|
| S.No. | Name of State/Region | Load | Month: | Nov'23 | |
| | | Peak Load (MW) | Off Peak Load (MW) | Peak (MW) | Off Peak (MW) |
| I | NORTHERN REGION | | | | |
| 1 | Punjab | 6187 | 4320 | 4431 | 2467 |
| 2 | Haryana | 6301 | 4633 | 2327 | 2029 |
| 3 | Rajasthan | 14634 | 8276 | 8964 | 6149 |
| 4 | Delhi | 4138 | 1632 | 530 | 506 |
| 5 | Uttar Pradesh | 15439 | 10852 | 10732 | 7505 |
| 6 | Uttarakhand | 1894 | 1473 | 383 | 297 |
| 7 | Himachal Pradesh | 1707 | 1017 | 546 | 240 |
| 8 | Jammu & Kashmir | 2488 | 2157 | 236 | 227 |
| 9 | Chandigarh | 197 | 89 | 0 | 0 |
| 10 | ISGS/PPs | 53 | 52 | 21207 | 9340 |
| | Total NR | 53038 | 34501 | 49356 | 28761 |
| II | EASTERN REGION | | | | |
| 1 | Bihar | 4303 | 3220 | 484 | 409 |
| 2 | Jharkhand | 1498 | 1268 | 436 | 409 |
| 3 | Damodar Valley Corporation | 3224 | 3002 | 5182 | 4218 |
| 4 | Odisha | 5447 | 4870 | 3217 | 2628 |
| 5 | West Bengal | 5848 | 4471 | 5542 | 4582 |
| 6 | Sikkim | 103 | 55 | 0 | 0 |
| 7 | Bhutan | 57 | 56 | 107 | 68 |
| 8 | ISGS/PPs | 748 | 698 | 14253 | 11518 |
| | Total ER | 21230 | 17642 | 29221 | 23833 |
| III | WESTERN REGION | | | | |
| 1 | Maharashtra | 24497 | 17173 | 16678 | 12825 |
| 2 | Gujarat | 18565 | 15139 | 8330 | 8534 |

| | | | | | |
|----|------------------------|--------|--------|--------|--------|
| 3 | Madhya Pradesh | 15672 | 9581 | 6140 | 4836 |
| 4 | Chattisgarh | 4723 | 3510 | 2439 | 2625 |
| 5 | Daman and Diu | 0 | 0 | 0 | 0 |
| 6 | Dadra and Nagar Haveli | 903 | 910 | 0 | 0 |
| 7 | Goa-WR | 538 | 427 | 0 | 0 |
| 8 | ISGS/IPPs | 5326 | 4186 | 46483 | 31327 |
| | Total WR | 70222 | 50926 | 80070 | 60147 |
| | | | | | |
| IV | SOUTHERN REGION | | | | |
| 1 | Andhra Pradesh | 10976 | 7444 | 6488 | 4721 |
| 2 | Telangana | 12210 | 9955 | 7160 | 4955 |
| 3 | Karnataka | 13204 | 8407 | 7228 | 5718 |
| 4 | Tamil Nadu | 16464 | 13330 | 9475 | 5630 |
| 5 | Kerala | 3474 | 3023 | 1037 | 583 |
| 6 | Pondy | 385 | 377 | 0 | 0 |
| 7 | Goa-SR | 90 | 88 | 0 | 0 |
| 8 | ISGS/IPPs | 0 | 0 | 19219 | 15358 |
| | Total SR | 56804 | 42625 | 50606 | 36964 |
| | | | | | |
| V | NORTH-EASTERN REGION | | | | |
| 1 | Arunachal Pradesh | 123 | 94 | 7 | 7 |
| 2 | Assam | 1193 | 1068 | 289 | 292 |
| 3 | Manipur | 188 | 118 | 0 | 0 |
| 4 | Meghalaya | 367 | 288 | 100 | 24 |
| 5 | Mizoram | 92 | 63 | 33 | 54 |
| 6 | Nagaland | 160 | 162 | 18 | 17 |
| 7 | Tripura | 214 | 229 | 164 | 159 |
| 8 | ISGS/IPPs | 0 | 0 | 2248 | 2153 |
| | Total NER | 2338 | 2022 | 2859 | 2707 |
| | | | | | |
| | Total All India | 203632 | 147716 | 212112 | 152412 |