National Load Despatch Centre Total Transfer Capability for October 2014

Issue Date: 2/10/2014 Issue Time: 0930 hrs Revision No. 4

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR-WR *	1st October 2014 to 31st October 2014	00-24	2500	500	2000	651	1349			
WR-NR	1st October 2014 to 31st October 2014	00-17 23-24	4900	500	4400	4380	20			
		17-23	4900		4400		20			
		00-06	1800		1600	293	1307			
NR-ER*	1st October 2014 to	06-17' 17-18'		200	800 1600	358 358	442 1242			
TAK-EK	31st October 2014	18-23	1800	200	900	293	607			
		23-24	1800		1600	293	1307			
ER-NR	1st October 2014 to	00-17 23-24	2800	300	2500	2431	69			
·	31st October 2014	17-23					69			
W3-ER ^{\$}	1st October 2014 to 31st October 2014	00-24	1600	300	1300	697	603			
ER-W3	1st October 2014 to 31st October 2014	00-24	1000	300	700	874	0			
WR-SR	1st October 2014 to 31st October 2014	00-24	2100	750	1350	1350	0			
SR-WR *	1st October 2014 to 31st October 2014	00-24				No	limit is being speified			
	1st October 2014	00-06	2650		2650	2585	65			
		18-24 06-08'	2650	0	2650	2650	0			
		08-18'	2450		2450	2650	0			
ER-SR	2nd October 2014 to 13th October 2014	00-06 18-24 06-18'	2650	0	2650	2370 2435	280 215		LTA revised till further orders from CERC	
	14th October 2014 to 31st October 2014	00-06 18-24	2650	0	2650	2585	65			
	1st October 2014 to	06-18'			2650		0			
SR-ER *	31st October 2014	00-24				No I	limit is being specified			
	1st October 2014 to	00-06 23-24	700		660	210	450			
ER-NER	31st October 2014 to	06-17'	700	40	660 560	210	450 250			
	2011	17-18 18-23	600		560 560	210 210	350 350			
NER-ER	1st October 2014 to	00-17 23-24	690	100	590	0	590			
	31st October 2014	17-23	530		430		430			
	1st October 2014	00-24	3785	300	3485	2946	539			
	2nd October 2014 to 5th October 2014	00-24	3050	300	2750	2837	0			
	6th October 2014 to 14th October 2014 15th October 2014 to	00-24	2750	300	2450	2764	0			
S1-S2	18th October 2014 to 18th October 2014	00-24	2750	300	2450	2728	0			
	19th October 2014	00-24	2750	300	2450	2651	0			
	20th October 2014 to 28th October 2014	00-24	2750	300	2450	2651	0			
	29th October 2014 to 30th October 2014	00-24	2750	300	2450	2651	0			
	31st October 2014	00-24	2750	300	2450	2687	0			

National Load Despatch Centre Total Transfer Capability for October 2014

Issue Date: 2/10/2014 Issue Time: 0930 hrs Revision No. 4

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
Import of Punjab	1st October 2014 to 31st October 2014	00-24	5700	300	5400	3790	1610		
Import TTC for DD & DNH	1st October 2014 to 31st October 2014	00-24	1200	0	1200	LTA and MTOA as per ex-pp schedule			
W3 zone Injection	1st October 2014 to 31st October 2014	00-17 23-24 17-23	9400 9900	200	9200 9700	6843	2357 2857		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

- \$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor.
- 1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
- 2) S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
- 3) W3 comprises of the following regional entities:
- a) Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL n) Vandana Vidyut
- # The figure is based on LTA/MTOA approved by CTU. In actual Operation, due to Units being on Maintenance/ Fuel shortage the LTA/MTOA utilized would vary.

 RLDC/NLDC would factor this situation on day ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak
WR-NR	High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
NR-ER	(n-1) contingency of 400 kV Sarnath-Pusauli
ER-NR	High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) due to transit flows on ER-WR-NR corridor.
W3-ER	(n-1) contingency of one circuit of 400kV MPL-Maithon D/C
ER-W3	(n-1) contingency of 400kV Raigarh-Jharsuguda-Rourkela
	1. (n-1) contingency of 400kV Parli(PG)-Sholapur(PG) D/C
WR-SR & ER-SR	2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.
SR-WR	Bhadrawati HVDC B/B link capacity
SR-ER	(n-1) contingency of one circuit of 400kV Talcher-Rourkela D/C
ER-NER	Palatana unit tripping leading to the thermal overloading of 220 kV BTPS - Salakati D/C
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa and High loading of 220kV Misa-Samaguri D/C
S1-S2	(n-1) contingency of one circuit of 400 kV Kolar-Hosur D/C line
Import of Punjab	(n-1) contingency of ICT at Patiala/Moga
W3 zone Injection	(n-1-1) contingency of one circuit of 400 kV Raipur-Bhadrawati D/C section
	*D.:

^{*}Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st October 2014 to	00-17 23-24	7700	800	6900	6811	89		
111	31st October 2014	17-23	7700		6900	0011	89		
	1st October 2014 to 31st October 2014	00-06 23-24	700	40	660	210	450		
NER		06-17'	700		660	210	450		
		17-18	600		560	210	350		
		18-23	600		560	210	350		
WR									

	1st October 2014	00-06 18-24	4750	750	4000	3935	65		
	18t October 2014	06-08'	4750	730	4000	4000	0		
		08-18'	4550		3800	4000	0		
SR	2nd October 2014 to	00-06 18-24	4750	750	4000	3720	280		LTA revised till further orders from CERC
	13th October 2014	06-18'	4750		4000	3785	215		OLUCIS HOIH CERC
	14th October 2014 to 31st October 2014	00-06 18-24	4750	750	4000	3935	65		
		06-18'	4750		4000	4000	0		

Simultaneous Export Capability

Corridor	Date	Time	Total	Reliability	Available	Long Term	Margin	Changes	Comments
		00-06	3500		2800	944	1856		
	1st October 2014 to	06-17'	3300		2800	1009	1791		
NR*	31st October 2014	17-18'	3600	700	2900	1009	1891		
	31st October 2014	18-23	3000		2900	944	1956		
		23-24	3500		2800	944	1856		
	1st October 2014 to 31st October 2014	00-17	690	100	590		590		
NER		23-24	090		390	0	390		
NEK		17-23	530		430	O	430		
		17-23	330		430		450		
WR									

SR *	* 1st October 2014 to 00-24 No limit is being specified								
SK	31st October 2014 00-24 No minit is being specified								

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

	Import	(n-1) contingencies of one circuit of 400KV Farakka-Malda D/C & (n-1) contingency of one circuit of 400KV						
	Import	High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop						
NR		(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.						
NIX	Export							
		(n-1) contingency of 400 kV Sarnath-Pusauli						
NER	Import	Palatana unit tripping leading to the thermal overloading of 220 kV BTPS - Salakati D/C						
MEK	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa and Hihg loading of 220kV Misa-Samaguri D/C						
		1. (n-1) contingency of 400kV Parli(PG)-Sholapur(PG) D/C						
SR	Import	2. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.						

National Load Despatch Centre Total Transfer Capability for October 2014

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected			
			STOA Margin revised due correction in LTA/ MTOA/ Allocation.				
	08-08-2014	Whole Month	Revised due to commissioning of contingency arrangement of one 500 MW Vindhyachal (Unit-12) with 400kV Vindhyachal-Rihand line.	WR-NR			
1			Revised due to commissioning of 765kV Sholapur-Raichur Circuit-2 and 765kV Wardha-Aurangabad D/C. The LTA/MTOA figures are based on allocations and the meetings on TTC/ATC taken by CTU on 24th and 30th Jul 2014. Any margins on account of less LTA/MTOA would be offered on day ahead basis.	WR-SR/ ER- SR			
			Revised due to commissioning of 400/220KV 2X315MVA ICT at Kala S/S along with 220kV Kala-Sayali and 220KV Kala-Khadoli lines	Import TTC for DD & DNH			
	25 00 2044	Whole	LTA/MTOA revised by CTU. MTOA from MP to Bescom (KPTCL) = 111 MW, MTOA from KSEB to Chattishgarh = 100 MW. TNEB got 365 MW LTA from WR (Jindal-150MW(earlier), KSK Mahanadi =179 MW, BALCO = 36 MW)	ER-SR			
2	26-09-2014	month	Revised due to commissioning of 400kV Tiruvalam- Kalivendapattu DC line, 400kV Kalivendapattu- Pugalur-1 & Tiruvalam 230kV line and LGBR Changes.	S1-S2			
		01-10-2014	Revised due to the outage of Vallur Unit-2 and NCTPS St-2 Unit-1	S1-S2			
2	30-09-2014	01-10-2014	-2014 Revised due to shutdown of 220kV Jeypore-Jayanagar ckt 1 and ckt 2 one at a time				
3		Whole Month	Revised after the reassessment of TTC due to the commissioning of the new elements in NER	ER-NER			
		Whole Month	Revised considering the present inter-regional flow pattern and transit flows from ER to NR via WR	ER-NR			
4	02-10-2014	02-10-2014 to 31-10-2014	LTA revised till further orders from CERC	ER-SR			