

National Load Despatch Centre
Total Transfer Capability for October 2015

Issue Date: 20/07/2015

Issue Time: 1630 hrs

Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st Oct 2015 to 31st Oct 2015	00-24	2500	500	2000	706	1294		
WR-NR*	1st Oct 2015 to 31st Oct 2015	00-24	5100	500	4600	5446	0		
NR-ER*	1st Oct 2015 to 31st Oct 2015	00-06	2000	200	1800	293	1507		
		06-18'	2000		1800	358	1442		
		18-24	2000		1800	293	1507		
ER-NR**	1st Oct 2015 to 31st Oct 2015	00-24	4800	300	4500	2431	2069		
W3-ER ^s	1st Oct 2015 to 31st Oct 2015	00-24	No limit is being specified. No Re-routing is allowed via W3-ER-NR.						
ER-W3	1st Oct 2015 to 31st Oct 2015	00-24	1000	300	700	874	0		
WR-SR	1st Oct 2015 to 31st Oct 2015	00-24	2300	750	1550	1550	0		
SR-WR *	1st Oct 2015 to 31st Oct 2015	00-24	No limit is being Specified.						
ER-SR	1st Oct 2015 to 31st Oct 2015	00-06 18-24	2650	0	2650	2585	65		STOA Margin revised considering CERC order dated 03-07-2015 in petition No- 92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.
		06-18'				2650	0		
SR-ER *	1st Oct 2015 to 31st Oct 2015	00-24	No limit is being Specified.						
S1-S2 (Rev 0)	1st to 2nd	00-24	4040	320	3720	2496	1224		
	3rd to 10th	00-24				2573	1147		
	11th to 14th	00-24	3775		3455	2663	792		
	15th to 21st	00-24				2507	948		
	22nd	00-24				2587	868		
	23rd	00-24				2676	779		
	24th to 31st	00-24				2467	988		
ER-NER	1st Oct 2015 to 31st Oct 2015	00-17 23-24	1390	45	1345	210	1135		
		17-23					1135	880	
NER-ER	1st Oct 2015 to 31st Oct 2015	00-17 23-24	1415	45	1370	0	1370		
		17-23					1250	45	
W3 zone Injection	1st Oct 2015 to 31st Oct 2015	00-17 23-24	9400	200	9200	7104	2096		
		17-23					9900	9700	

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

National Load Despatch Centre
Total Transfer Capability for October 2015

Issue Date: 20/07/2015

Issue Time: 1630 hrs

Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------	---------------------------------	--------------------	-------------------------------------	--	--	-------------------------------------	----------

S1-S2 Corridor: Any revision in S1-S2 TTC/ATC from Rev-0, would be uploaded under Intra-Regional Section on NLDC website.

\$ As per Simulations, predominant direction of flow is on West to North Corridor. Hence, in case injection point is in Western Region (W1,W2,W3), STOA/PX transactions from West to North on West-East-North corridor shall not be allowed as such transaction increases congestion in the West to North Corridor. & ER-NR TTC is independent of WR-NR corridor flow

- 1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu, Kerala and Puducherry
- 2) W3 comprises of the following regional entities :
 - a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
 - f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Sipat, j) Korba, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidut

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown :

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	High Loading of 400kV Singrauli-Anpara & High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and Loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	N-1 contingency of 400 kV Biharshariff- Lakhisarai S/C
ER-W3	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular Octaration between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)
WR-SR & ER-SR	1. (n-1) of 400 kV Wardha – Parli will lead to 30 degrees angular Octaration between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG) 3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.
ER-NER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
W3 zone Injection	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular Octaration between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)

*Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR*	1st Oct 2015 to 31st Oct 2015	00-24	7300	800	6500	7877	0		
NER	1st Oct 2015 to 31st Oct 2015	00-17	1390	45	1345	210	1135		
		23-24	1135		1090		880		
WR									
SR	1st Oct 2015 to 31st Oct 2015	00-06	4950	750	4200	4135	65		STOA Margin revised considering CERC order dated 03-07-2015 in petition No- 92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.
		18-24	4950		4200	4200	0		

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st Oct 2015 to 31st Oct 2015	00-06	4500	700	3800	999	2801		
		06-18'			3800	1064	2736		
		18-24			3800	999	2801		
NER	1st Oct 2015 to 31st Oct 2015	00-17	1415	45	1370	0	1370		
		23-24	1250	45	1205		1205		
WR									
SR *	1st Oct 2015 to 31st Oct 2015	00-24	No limit is being Specified.						

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints

NR	Import	(n-1) contingency of 400 kV Biharshariff- Lakhisarai S/C High loading of 765 kV Agra-Gwalior (1250 MW SPS setting on each circuit of 765 kV Gwalior-Agra) and high loop flows on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda (power flowing from WR to NR on 765kV Gwalior-Agra D/C and from NR to WR on 400kV Kankroli-Zerda and 400kV Bhinmal-Zerda).
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli
NER	Import	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
	Export	
SR	Import	1. n-1 of 400 kV Wardha – Parli will lead to 30 degrees angular separation between Wardha and Parli. 2. (n-1) contingency of one circuit of 400kV Parli(PG)-Sholapur(PG)
		3. ER-SR TTC has been declared assuming more than 1100 MW generation at Talcher Stage-2. In case Talcher Stage-2 generation goes below 1100 MW, then the ER-SR TTC would be revised downward as constraints within ER would emerge.

*Primary constraints

ASSUMPTIONS IN BASECASE					
				Month : October '15	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7657	6004	4196	4242
2	Haryana	7576	6766	3317	3317
3	Rajasthan	9178	9897	6114	6110
4	Delhi	4449	2882	1156	1156
5	Uttar Pradesh	12168	10933	5913	5851
6	Uttarakhand	1573	1277	556	404
7	Himachal Pradesh	1253	978	418	435
8	Jammu & Kashmir	2244	1746	240	232
9	Chandigarh	238	147	0	0
10	ISGS/IPPs	0	0	18220	12306
	Total NR	46336	40630	40130	34053
II	EASTERN REGION				
1	Bihar	2686	1884	240	120
2	Jharkhand	995	793	552	300
3	Damodar Valley Corporation	2487	2030	3831	3261
4	Orissa	3593	2796	3378	2483
5	West Bengal	7396	6253	5086	4000
6	Sikkim	99	59	0	0
7	Bhutan	338	337	1490	1150
8	ISGS/IPPs	610	566	11062	9925
	Total ER	18204	14717	25639	21239
III	WESTERN REGION				
1	Maharashtra	20077	12639	14900	8194
2	Gujarat	14392	8618	11287	5509
3	Madhya Pradesh	8008	5948	4832	3049
4	Chattisgarh	3838	3825	2611	2851
5	Daman and Diu	310	237	0	0
6	Dadra and Nagar Haveli	784	581	0	0
7	Goa-WR	521	298	0	0
8	ISGS/IPPs	1056	1055	23713	21264
	Total WR	48986	33200	57341	40867

IV	SOUTHERN REGION				
1	Andhra Pradesh	5870	5494	5192	4701
2	Telangana	7082	6346	3246	2362
3	Karnataka	7654	5943	7091	5422
4	Tamil Nadu	12244	10949	6990	5376
5	Kerala	3271	2218	1782	820
6	Pondy	323	278	0	0
7	Goa-SR	86	76	0	0
8	ISGS/IPPs	0	0	9622	9622
	Total SR	36530	31304	33923	28303
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	107	44	0	0
2	Assam	969	719	265	195
3	Manipur	113	69	0	0
4	Meghalaya	295	197	214	163
5	Mizoram	76	44	4	4
6	Nagaland	95	70	16	6
7	Tripura	260	162	105	105
8	ISGS/IPPs	7	7	1313	856
	Total NER	1922	1312	1917	1329
	Total All India	151979	121164	158951	125791