				Load Desp sfer Capabi					
Issue Date	: 28th July, 202	21	Issu	e Time: 170	0 hrs		R	evision No	o. 2
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-06				378	1622		Revised STOA margin due to - a) Increase in LTA from Rihand to MP by 4.5MW (from 45 MW to 49.5 MW)
NR-WR*	1st October 2021 to 31st October 2021	06-18	2500	500	2000	1206	794		 b) Increase in LTA from Matalia to MP by 40 MW (from 10 MW to 50 MW) c) Decrease in LTA from Rajasthan solar to MP by 5 MW (from 10 MW to 5 MW) d) Increase in LTA from Rajasthan solar to Chattisgarh by 5 MW (from 5 MW to 10 MW)
		18-24				378	1622		e) ARERJL MTOA of 200 MW to Maharashtra has endedf) NR ISGS allocation to Gujrat increased from 58 MW to 80 MW
		00-06	18450	1000	17450 16500**	11267 10317**	6183		Revised STOA margin due to -
			17500**						a) Increase in LTA from RWE_APL2_SECI-III(Ghadsisa) to Haryana by 22 MW (from 241
WR-NR*	1st October 2021 to 31st	06-18	18450	1000	17450	11656	5794		MW to 263 MW)
	October 2021		17500**		16500**	10706**			b) LTA of 228 MW from PGLR_SREPL to UPPCL (SR-WR-NR)
		18-24	18450 17500**	1000	17450 16500**	11267 10317**	6183		c) LTA of 6.9 MW from Rajghat, MP to UPPCL
NR-ER*	1st October 2021 to 31st	00-06 06-18	2000 2000	200	1800 1800	193 603	1607 1197	-	
ER-NR*	October 2021 1st October 2021 to 31st October 2021	18-24 00-24	2000 6850	400	1800 6450	193 4280	1607 2170		
	1st October								
W3-ER	2021 to 31st October 2021	00-24		No limit is being specified.					s being specified.
ER-W3	1st October 2021 to 31st October 2021	00-24						No limit is	s being specified.
	1st October	00-05	9350		8700		5104		
WR-SR [^]	2021 to 31st October 2021	05-22 22-24	9350 9350	650	8700 8700	3596	5104 5104		Revised STOA as unallocated power of 300 MW from NTPC-WR to Karnataka revised to 0 M
SR-WR *	1st October 2021 to 31st	00-24	4600	400	4200	845	3355		Revised STOA margin due to LTA of 228 MW from PGLR_SREPL to UPPCL (SR-WR-NR
	October 2021								
	1st October	00-06				2672	2728		
ER-SR [△]	2021 to 31st October 2021	06-18	5750	350	5400	2757 2672	2643 2728		
SR-ER *	1st October 2021 to 31st October 2021	00-24				2072	2720	No limit is	s being Specified.
		00-02	810		765	474	291		
	1st Ostober	02-07	810		765	474	291		
ER-NER*	1st October 2021 to 31st	07-12	805	45	760	474	286	-	
	October 2021	12-18 18-22	820 610		775 565	474 474	<u> </u>	-	
		22-24	810		765	474	291		
		00-02	3280		3235	83	3152		
	1st October	02-07	3280		3235	83	3152	-	
		07-12	3230	15	3185	83	3102	-	
NER-ER*	2021 to 31st	12-18	3270	45	3225	83	3142		
NER-ER*	2021 to 31st October 2021	12-18 18-22	3270 3240	43	3225 3195	83 83	3142 3112		

				-	patch Cent ility for Oct						
Issue Date	: 28th July, 20	21	Issu	e Time: 170	0 hrs		Revision No. 2				
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments		
W3 zone Injection	1st October 2021 to 31st October 2021	00-24	No limit is be	ing specified (In case of any o	constraints appeari	ng in the system, W	/3 zone expor	t would be revised accordingly)		
Note: TTC/	ATC of S1-(S2&	&S3) corridor, Impo	ort of S3(Kera	la), Import of	Punjab and I	mport of DD & I	ONH is uploaded	on NLDC we	ebsite under Intra-Regional Section in Monthly ATC.		
* Fifty Perce	nt (50 %) Count	er flow benefit on acc	count of LTA/M	ATOA transact	tions in the reve	erse direction woul	ld be considered fo	r advanced tra	ansactions (Bilateral & First Come First Serve).		
**Considerir NR regional	-	d stage-III - Vindhyac	chal PS D/C lin	e as inter-regio	onal line for the	purpose of schedu	aling, metering and	accounting a	nd 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as		
 2) W3 comp. a) Chattisgarl f) BALCO, g and any other # The figure Fuel shortage In the eventu 	rises of the follow h Sell transaction,) Sterlite (#1,3,4) regional entity ge is based on LTA e/New units being ality that net sche	AP and Karnataka; S2 ving regional entities : , b) Jindal Power Limit , h) NSPCL, i) Korba, enerator in Chhattisgar /MTOA approved by g commissionned the edules exceed ATC, r	ted (JPL) Stage j) Sipat, k) KS th CTU and Allo LTA/MTOA	-I & Stage-II, c K Mahanadi, L cation figures a utilized would	e) Jindal Steel as DB Power, m) as per RPCs R ¹ vary. RLDC/N	nd Power Limited () KWPCL, n)Vanda TA/REA. In actual	JSPL), d) ACBL, e) ana Vidyut o)RKM, l Operation, due to	p)GMR Raik Units being o	heda, q)Ind Barath n Maintenance/		
1) The TTC	value will be rev	to any shutdown : vised to normal values vised to normal values				time.					
Real Time T	TC/ATC revisior	ns are uploaded on PC)SOCO/NLDC	C "News Updat	e" (Flasher) Se	ection					
-	^Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.										
^In case of d	rawl of Karnatak	a beyond 3800 MW,	the voltages in	Bengaluru are	a are observed	to be critically low	7. This issue may b	e taken care o	f by Karnataka SLDC by taking appropiate measures.		
SR-WR TTC	C/ATC figures ha	we been calculated co	onsidering 01 u	nit (800 MW)	at Kudgi TPS i	n service. The figu	res are subject to c	hange with ch	nange in generation at Kudgi TPS.		
WR-NR/Imp	oort of NR TTC h	has been calculated co	onsidering gene	ration at Parico	cha TPS as 350) MW. TTC figure	s are subject to cha	nge with sign	ificant change in generation at Pariccha TPS.		

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-06	25300		23900	15547	8353		Revised STOA margin due to -
	1st October 2021 to 31st October 2021		24350**		22950**	14597**	0000		<u>-</u>
		06-09	25300		23900	15936	7964	a) Increase in LTA from RWE_APL2_SECI-III(Ghadsisa) to	
		00 09	24350**		22950**	14986**	7701		Haryana by 22 MW (from 241 MW to 263 MW)
NR			25300	1400	23900	15936			b) LTA of 228 MW from
		09-17	24350**		22950**	14986**	7964		PGLR_SREPL to UPPCL (SR-WR-NR)
			25300		23900	15936			c) LTA of 6.9 MW from Rajghat, MP
		17-18	24350**		22950**	14986**	7964		to UPPCL
			25300	-	23900	15547			
		18-24	18-24				8353		
			24350**		22950**	14597**			
		00-02	810		765	474	291		
	1st October	02-07	810		765	474	291		
NER [*]	2021 to 31st	07-12		45	760	474	286		
	October 2021	12-18	820		775	474	301		
		18-22	610		565	474	91		
		22-24	810		765	474	291		
WR [*]									
		00-06	15100		14100	6270	7830		
ФЦ	1st October	06-18	15100		14100	6355	7745		Revised STOA as unallocated power of
SR ^{*#}	2021 to 31st October 2021	18-24	15100	1000	14100	6270	7830		300 MW from NTPC-WR to Karnataka revised to 0 MW

* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A WR-NR ATC =B ER-NR ATC = C

Margin for WR-NR applicants = A * B/(B+C)Margin for ER-NR Applicants = A * C/(B+C)

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments		
		00-06				571	3229		Revised STOA margin due to -		
	1st October 2021 to 31st October 2021	06-18	4500	700	3800	1809	1991		 a) Increase in LTA from Rihand to MP by 4.5MW (from 45 MW to 49.5 MW) b) Increase in LTA from Matalia to MP by 40 MW (from 10 MW to 50 MW) c) Decrease in LTA from Rajasthan solar to MP by 5 MW (from 10 MW to 5 MW) d) Increase in LTA from Rajasthan solar to Chattisgarh by 5 MW (from 5 MW to 10 MW) 		
		18-24				571	3229		e) ARERJL MTOA of 200 MW to Maharashtra has endedf) NR ISGS allocation to Gujrat increased from 58 MW to 80 MW		
	1st October 2021 to 31st October 2021	00-02	3280		3235	83	3152				
		02-07	3280		3235	83	3152				
NER*		07-12	3230	45	3185	83	3102				
NEK*		12-18	3270		3225	83	3142				
		18-22	3240			3	3195	83	3112		
		22-24	3280		3235	83	3152				
WR*											
SR*^	1st October 2021 to 31st October 2021	00-24	3700	400	3300	1564	1736		Revised STOA margin due to LTA of 228 MW from PGLR_SREPL to UPPCL (SR-WR-NF		

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

Limiting	Constraints (Corridor wise)	
		Applicable Revisions
Corridor	Constraint	
WR-NR	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 1 to 2
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 1 to 2
ER-NR	Inter-regional flow pattern towards NR	Rev- 1 to 2
WR-SR	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	
and ER-	N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit	Rev- 1 to 2
SR	Low Voltage at Gazuwaka (East) Bus.	
$\mathbf{N}\mathbf{P} = \mathbf{W} \mathbf{P}$	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 1 to 2
ER-NER	 a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C 	Rev- 1 to 2
NER-ER	 a) N-1 contingency of 220 kV Salakati - Alipurduar I or II b) High Loading of 220 kV Salakati - Alipurduar II or I 	Rev- 1 to 2
W3 zone Injection		Rev- 1 to 2

Limiting Constraints (Simultaneous)

Applicable Revisions

			repricable revisions
NR	Immont	Inter-regional flow pattern towards NR	Rev- 1 to 2
INK	Import	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 1 to 2
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	Rev- 1 to 2
	Ехрогі	(n-1) contingency of 400 kV Saranath-Pusauli	Kev- 1 to 2
		a) N-1 contingency of 400 kV Bongaigaon - Killing line (0000 hrs to 2400 hrs)	
	Import	b) High Loading of 220 kV Balipara-Sonabil (0000 hrs to 0700 hrs)	Rev- 1 to 2
NER		c) High Loading of 220 kV Salakati - BTPS D/C (0700 hrs to 1200 hrs)	
	Export	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II	D 1 4. 2
		b) High Loading of 220 kV Salakati - Alipurduar II or I	Rev- 1 to 2
		N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	
	Import	N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit	Rev- 1 to 2
SR	_	Low Voltage at Gazuwaka (East) Bus	
	Export	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt	Rev- 1 to 2
	Export	N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Kev- 1 to 2

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected	
1	17th July 2021	Whole month	Revised Reliability Margin (TRM) considering 2% of the total	WR-NR, ER-NR &	
Ţ	17th July 2021	whole month	anticipated peak demand met in MW in NR Import	NR Import	
			Revised STOA margin due to -		
			a) Increase in LTA from Rihand to MP by 4.5MW (from 45 MW		
			to 49.5 MW)		
			b) Increase in LTA from Matalia to MP by 40 MW (from 10 MW		
			to 50 MW)		
			c) Decrease in LTA from Rajasthan solar to MP by 5 MW (from	NR-WR/ NR Export	
		Whole month	10 MW to 5 MW)		
			d) Increase in LTA from Rajasthan solar to Chattisgarh by 5 MW		
			(from 5 MW to 10 MW)		
	28th July 2021		e) ARERJL MTOA of 200 MW to Maharashtra has ended		
2			f) NR ISGS allocation to Gujrat increased from 58 MW to 80		
			MW		
			Revised STOA margin due to -		
			a) Increase in LTA from RWE_APL2_SECI-III(Ghadsisa) to		
			Haryana by 22 MW (from 241 MW to 263 MW)	WR-NR/NR Import	
			b) LTA of 228 MW from PGLR_SREPL to UPPCL (SR-WR-NR)		
			c) LTA of 6.9 MW from Rajghat, MP to UPPCL		
			Revised STOA as unallocated power of 300 MW from NTPC-WR	WR-SR/ SR Import	
			to Karnataka revised to 0 MW		
			Revised STOA margin due to LTA of 228 MW from PGLR_SREPL	SR-WR/SR Export	
			to UPPCL (SR-WR-NR)		

National Load Despatch Centre Total Transfer Capability for October 2021

ASSUN	MPTIONS IN BASECASE						
				Month : October 2021			
S.No.	Name of State/Area		Load	Generation			
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)		
	NORTHERN REGION						
1	Punjab	10744	10867	3971	3971		
2	Haryana	9492	9088	2701	2701		
3	Rajasthan	10485	9635	8259	8259		
4	Delhi	5321	5152	796	795		
5	Uttar Pradesh	20631	20099	10623	10689		
6	Uttarakhand	2124	1886	928	939		
7	Himachal Pradesh	1354	1114	783	769		
8	Jammu & Kashmir	2363	1962	884	883		
9	Chandigarh	313	249	0	0		
10	ISGS/IPPs	48	48	21958	20013		
	Total NR	62875	60100	50903	49019		
II	EASTERN REGION						
1	Bihar	6537	5617	356	349		
2	Jharkhand	1958	1503	511	501		
3	Damodar Valley Corporation	2985	2723	5856	4190		
4	Orissa	4513	4310	3998	3798		
5	West Bengal	9704	8401	7033	6210		
6	Sikkim	119	116	0	0		
7	Bhutan	181	181	2325	2325		
8	ISGS/IPPs	810	810	15771	11533		
	Total ER	26808	23662	35850	28906		
	WESTERN REGION						
1	Maharashtra	17405	16509	11624	10789		
2	Gujarat	13918	11320	8601	7246		
3	Madhya Pradesh	9254	8534	3596	3845		
4	Chattisgarh	4309	3965	2531	2835		
5	Daman and Diu	276	236	0	0		
6	Dadra and Nagar Haveli	744	870	0	0		
7	Goa-WR	534	420	0	0		
8	ISGS/IPPs	1784	3263	36712	32338		
	Total WR	48224	45117	63064	57053		

IV	SOUTHERN REGION				
1	Andhra Pradesh	8024	7220	6268	5204
2	Telangana	9100	8117	5196	5078
3	Karnataka	8396	6654	6023	4850
4	Tamil Nadu	15210	13068	7256	6376
5	Kerala	3778	2349	1614	961
6	Pondy	264	264	0	0
7	Goa-SR	82	82	0	0
8	ISGS/IPPs	37	37	14805	14794
	Total SR	44891	37791	41162	37263
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	140	95	118	118
2	Assam	1849	1588	615	574
3	Manipur	207	86	105	103
4	Meghalaya	315	255	302	229
5	Mizoram	150	55	60	60
6	Nagaland	173	155	96	93
7	Tripura	435	260	300	300
8	ISGS/IPPs	0	0	2371	2370
	Total NER	3269	2494	3967	3847
	Total All India	186067	169164	194946	176088