	National Load Despatch Centre Total Transfer Capability for October 2021									
Issue Date:	25th Septembe	er, 2021	Issu	e Time: 170	0 hrs		Revision No. 5			
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
		00-06				378	1622			
NR-WR*	1st October 2021 to 31st October 2021	06-18	2500	500	2000	1206	794			
		18-24				378	1622			
						11279				
		00-06	19500 18550**	1000	18500 17550**	10329**	7221			
WR-NR*	1st October 2021 to 31st October 2021	06-18	19500 18550**	1000	18500 17550**	11668 10718**	6832			
		18-24	19500	1000	18500	11279	7221			
			18550**		17550**					
	1st October	00-06	2000		1800	93	1707	1		
NR-ER*	2021 to 31st	06-18	2000 2000	200	1800	93	892	•		
	October 2021	18-24	2000		1800	93	1707			
ER-NR*	1st October 2021 to 31st October 2021	00-24	5900	400	5500	4372	1128			
W3-ER	1st October 2021 to 31st October 2021	00-24	No limit is being specified.							
ER-W3	1st October 2021 to 31st October 2021	00-24						No limit is	being specified.	
	1-t O-t-h-r	00-05	10350		9700		6104	1000		
WR-SR <sup>^</sup>	1st October 2021 to 31st	05-22	10350	650	9700	3596	6104	1000	TTC/ATC revised due to commissioning of HVDC Raigarh-Pugalur Pole-3	
	October 2021	22-24	10350		9700		6104	1000		
SR-WR *	1st October 2021 to 31st October 2021	00-24	4600	400	4200	857	3343			
		00-06				2672	2778	50		
ER-SR <sup>▲</sup>	1st October 2021 to 31st		5800	350	5450	2672	2693	50	TTC/ATC revised due to commissioning of HVDC Raigarh-Pugalur Pole-3	
EK-SK	October 2021		5800	330	5450				TOATC revised due to commissioning of HVDC Kaigam-Pugatur Pole-3	
	1.0.1	18-24				2672	2778	50		
SR-ER *	1st October 2021 to 31st October 2021	00-24						No limit is	being Specified.	
		00-02	810		765	455	310			
	1st October	02-07	810		765	455	310			
ER-NER*	2021 to 31st	07-12	805	45	760	455	305			
	October 2021	12-18 18-22	820 610		775 565	455 455	320 110			
		22-24	810		765	455	310			
		00-02	3280		3235	131	3104			
	1st October	02-07	3280		3235	131	3104			
NER-ER*	2021 to 31st	07-12 12-18	3230 3270	45	3185 3225	131	3054 3094			
	October 2021	18-22	3240		3195	131	3064			
		22-24	3280		3235	131	3104			
W3 zone Injection	1st October 2021 to 31st October 2021	00-24	No limit is be	ing specified (I	in case of any c	onstraints appearir	ng in the system, W	3 zone export	t would be revised accordingly)	
Note: TTC/A	ATC of S1-(S2&:	83) corridor, Impor	t of S3(Kerala	ı), Import of F	unjab and Im	port of DD & DN	H is uploaded on	NLDC webs	site under Intra-Regional Section in Monthly ATC.	

	National Load Despatch Centre Total Transfer Capability for October 2021										
Issue Date:	25th Septemb	er, 2021	Issu	ue Time: 170	0 hrs	Revision No. 5					
Corridor	dor Date Time Period (hrs) Tansfer Capability (TTC) Transfer (Capability (TTC)) Transfer (Capability (TTC)) Transfer Capability (TTC) Transfer Capability (ATC) Transfer (Capability (ATC)) Transfer Capability (ATC) Transfer (Capability (ATC)) Transfer (Capability (CT)) Transfer (CT)) Transfer (CT) Transfer (CT) Transfer (CT)) Transfer (CT) Transfer (CT) Tr						Comments				
* Fifty Perce	nt (50 % ) Counte	er flow benefit on acco	ount of LTA/N	ITOA transact	ions in the reve	rse direction woul	d be considered for	r advanced tra	nsactions (Bilateral & First Come First Serve).		
**Considerir regional entit	e	l stage-III - Vindhyach	nal PS D/C line	e as inter-regio	nal line for the	purpose of schedu	ling, metering and	accounting an	d 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR		
<ol> <li>W3 compi a) Chattisgarl f) BALCO, g and any other</li> <li># The figure</li> <li>Fuel shortage In the eventu</li> <li>In case of TI</li> <li>The TTC</li> </ol>	<ul> <li>1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala</li> <li>2) W3 comprises of the following regional entities : <ul> <li>a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I &amp; Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak</li> <li>f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath</li> <li>and any other regional entity generator in Chhattisgarh</li> </ul> </li> <li># The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC. In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values after restoration of shutdown. </li> </ul>										
Real Time T	FC/ATC revision	s are uploaded on PO	SOCO/NLDC	"News Update	e" (Flasher) Sec	tion					
^Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.											
^In case of d	^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropriate measures.										
SR-WR TTC	/ATC figures hav	ve been calculated cor	nsidering 01 ur	nit (800 MW) a	nt Kudgi TPS in	service. The figur	res are subject to ch	nange with cha	ange in generation at Kudgi TPS.		
WR-NR/Imp	ort of NR TTC h	as been calculated cor	nsidering gener	ration at Parice	ha TPS as 350	MW. TTC figures	are subject to char	nge with signif	ficant change in generation at Pariccha TPS.		

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-06	25400		24000	15651	8349		
			24450**		23050**	14701**			
		06-09	25400		24000	16040	7960		
	1st October 2021 to 31st October 2021		24450**		23050**	15090**			
NR		09-17	25400	1400	24000	16040	7960		
			24450**		23050**	15090**			
		17-18	25400		24000	16040	7960		
			24450**		23050**	15090**			
		18-24	25400		24000	15651	8349		
			24450**		23050**	14701**			
		00-02	810		765	455	310		
	1st October 2021	02-07	810		765	455	310		
NER <sup>*</sup>	to 31st October	07-12 12-18	805 820	45	760 775	455 455	305 320		
	2021	12-18	610		565	455	110		
		22-24	810		765	455	310		
WR <sup>*</sup>									
•• <b>I</b>									
**	1st October 2021	00-06	16150		15150	6270	8880	1050	TTC/ATC revised due to commissioning
SR <sup>*#</sup>	to 31st October	06-18	16150	1000	15150	6355	8795	1050	of HVDC Raigarh-Pugalur Pole-3
	2021	18-24	16150		15150	6270	8880	1050	

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\*\*Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

\* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A WR-NR ATC =B ER-NR ATC = C

Margin for WR-NR applicants = A \* B/(B+C)Margin for ER-NR Applicants = A \* C/(B+C)

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
		00-06				471	3329			
NR*	1st October 2021 to 31st October 2021	06-18	4500	700	3800	2114	1686			
		18-24				471	3329			
		00-02	3280	3235	131	3104				
	1st October 2021 to 31st October 2021	02-07	3280	45	3235	131	3104			
NER*		07-12	3230		45 <u>3185</u> 3225	131	3054			
NEK		12-18	3270			3225	131	3094		
		18-22	3240		3195	131	3064			
		22-24	3280			3235	131	3104		
WR*										
SR*^	1st October 2021 to 31st October 2021	00-24	3700	400	3300	1586	1714			

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

Limiting	Constraints (Corridor wise)				
		Applicable Revisions			
Corridor	Constraint				
	N-1 contingency of 1500 MVA, 765/400 kV ICT at Agra will overload the other ICT	Rev 0			
WR-NR	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 1 to 2			
	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	Rev- 3 to 5			
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 5			
ER-NR	Inter-regional flow pattern towards NR	Rev- 0 to 5			
	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT				
WR-SR	N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit	Rev- 0 to 4			
and ER-	Low Voltage at Gazuwaka (East) Bus.				
SR	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev- 5			
	Low Voltage at Gazuwaka (East) Bus.	Kev- J			
SR-WR	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0 to 5			
ER-NER	<ul> <li>a) N-1 contingency of 400 kV Bongaigaon - Azara line</li> <li>b) High Loading of 220 kV Salakati - BTPS D/C</li> </ul>	Rev- 0 to 5			
NER-ER	<ul> <li>a) N-1 contingency of 220 kV Salakati - Alipurduar I or II</li> <li>b) High Loading of 220 kV Salakati - Alipurduar II or I</li> </ul>	Rev- 0 to 5			
W3 zone Injection		Rev- 0 to 5			

## Limiting Constraints (Simultaneous)

			Applicable Revisions
		Inter-regional flow pattern towards NR	Rev-0 to 5
NR	Import	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 0 to 2
		N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	Rev- 3 to 5
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	Rev- 0 to 5
	Export	Kev- 0 to 5	
		a) N-1 contingency of 400 kV Bongaigaon - Killing line (0000 hrs to 2400 hrs)	
	Import	b) High Loading of 220 kV Balipara-Sonabil (0000 hrs to 0700 hrs)	Rev- 0 to 5
NER		c) High Loading of 220 kV Salakati - BTPS D/C (0700 hrs to 1200 hrs)	
	E-m out	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II	Rev-0 to 5
	Export	b) High Loading of 220 kV Salakati - Alipurduar II or I	Rev- 0 to 5
		N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	
		N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit	Rev-0 to 4
	Import	Low Voltage at Gazuwaka (East) Bus	
SR		N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev- 5
		Low Voltage at Gazuwaka (East) Bus	Kev- J
	Export	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt	Rev- 0 to 5
	Export	N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Kev- 0 to 5

.. . . .

## National Load Despatch Centre Total Transfer Capability for October 2021

Revision No	Revision Revision		Reason for Revision/Comment	Corridor Affected WR-NR, ER-NR & NR Import	
1			Revised Reliability Margin (TRM) considering 2% of the total anticipated peak demand met in MW in NR Import		
2	28th July 2021	Whole month	Revised STOA margin due to - a) Increase in LTA from Rihand to MP by 4.5MW (from 45 MW to 49.5 MW) b) Increase in LTA from Matalia to MP by 40 MW (from 10 MW to 50 MW) c) Decrease in LTA from Rajasthan solar to MP by 5 MW (from 10 MW to 5 MW) d) Increase in LTA from Rajasthan solar to Chattisgarh by 5 MW (from 5 MW to 10 MW) e) ARERJL MTOA of 200 MW to Maharashtra has ended f) NR ISGS allocation to Gujrat increased from 58 MW to 80 MW Revised STOA margin due to -	NR-WR/ NR Export	
			<ul> <li>a) Increase in LTA from RWE_APL2_SECI-III(Ghadsisa) to Haryana by 22 MW (from 241 MW to 263 MW)</li> <li>b) LTA of 228 MW from PGLR_SREPL to UPPCL (SR-WR-NR)</li> <li>c) LTA of 6.9 MW from Rajghat, MP to UPPCL</li> </ul>	WR-NR/NR Import	
			Revised STOA as unallocated power of 300 MW from NTPC-WR to Karnataka revised to 0 MW Revised STOA margin due to LTA of 228 MW from PGLR_SREPL to UPPCL (SR-WR-	WR-SR/ SR Import	
3	24th August, 2021	Whole Month	NR) Revised TTC/ATC due to commissioning of 765kV Vindhyachal-Varanasi D/C	WR-NR, ER-NR & NR Import	
			Revised STOA margin due to increase in LTA from PGLR_SREPL to UP by 12 MW (from 228MW to 240 MW)	SR-WR/SR Export; WR NR/NR Import	
4	28th August, 2021	Whole Month	Revised STOA margin due to operationalisation of LTA of 73 MW from Tuticorin- BETAMWIND to UPPCL (SR-ER-NR)	ER-NR/NR Import	
			Revised STOA margin due to change in LTA allocations	NR-ER	
			Revised STOA margin due to change in LTA allocations	NER Import/Export	
5	25th September 2021	Whole Month	TTC/ATC revised due to commissioning of HVDC Raigarh-Pugalur Pole-3	WR-SR/ER-SR/SR Impo	

ASSUN	IPTIONS IN BASECASE					
				Month : October 2021		
S.No.	Name of State/Area		Load	Generation		
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)	
Ι	NORTHERN REGION					
1	Punjab	10744	10867	3971	3971	
2	Haryana	9492	9088	2701	2701	
3	Rajasthan	10485	9635	8259	8259	
4	Delhi	5321	5152	796	795	
5	Uttar Pradesh	20631	20099	10623	10689	
6	Uttarakhand	2124	1886	928	939	
7	Himachal Pradesh	1354	1114	783	769	
8	Jammu & Kashmir	2363	1962	884	883	
9	Chandigarh	313	249	0	0	
10	ISGS/IPPs	48	48	21958	20013	
	Total NR	62875	60100	50903	49019	
П	EASTERN REGION					
1	Bihar	6537	5617	356	349	
2	Jharkhand	1958	1503	511	501	
3	Damodar Valley Corporation	2985	2723	5856	4190	
4	Orissa	4513	4310	3998	3798	
5	West Bengal	9704	8401	7033	6210	
6	Sikkim	119	116	0	0	
7	Bhutan	181	181	2325	2325	
8	ISGS/IPPs	810	810	15771	11533	
	Total ER	26808	23662	35850	28906	
	WESTERN REGION					
1	Maharashtra	17405	16509	11624	10789	
2	Gujarat	13918	11320	8601	7246	
3	Madhya Pradesh	9254	8534	3596	3845	
4	Chattisgarh	4309	3965	2531	2835	
5	Daman and Diu	276	236	0	0	
6	Dadra and Nagar Haveli	744	870	0	0	
7	Goa-WR	534	420	0	0	
8	ISGS/IPPs	1784	3263	36712	32338	
	Total WR	48224	45117	63064	57053	

IV	SOUTHERN REGION				
1	Andhra Pradesh	8024	7220	6268	5204
2	Telangana	9100	8117	5196	5078
3	Karnataka	8396	6654	6023	4850
4	Tamil Nadu	15210	13068	7256	6376
5	Kerala	3778	2349	1614	961
6	Pondy	264	264	0	0
7	Goa-SR	82	82	0	0
8	ISGS/IPPs	37	37	14805	14794
	Total SR	44891	37791	41162	37263
oort of D	NORTH-EASTERN REGION				
1	Arunachal Pradesh	140	95	118	118
2	Assam	1849	1588	615	574
3	Manipur	207	86	105	103
4	Meghalaya	315	255	302	229
5	Mizoram	150	55	60	60
6	Nagaland	173	155	96	93
7	Tripura	435	260	300	300
8	ISGS/IPPs	0	0	2371	2370
	Total NER	3269	2494	3967	3847
	Total All India	186067	169164	194946	176088