

National Load Despatch Centre Total Transfer Capability for Oct 2023									
Issue Date:Sep 19 2023				Issue Time:17:50:36			Revision No :4		
Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
ER-NER	01 Oct to 31 Oct	00:00 to 07:00	800	60	740	455	285	0	
		07:00 to 12:00	805	60	745	455	290	0	
		12:00 to 18:00	780	60	720	455	265	0	
		18:00 to 22:00	765	60	705	455	250	0	
		22:00 to 24:00	800	60	740	455	285	0	
ER-NR	01 Oct to 31 Oct	00:00 to 24:00	8000	400	7600	5097	2503	0	
ER-SR	01 Oct to 31 Oct	00:00 to 06:00	5700	350	5350	3265	2085	0	
		06:00 to 18:00	5700	350	5350	3330	2020	0	
		18:00 to 24:00	5700	350	5350	3265	2085	0	
ER-W3	01 Oct to 31 Oct	00:00 to 24:00	No limit is being specified.						
ER-WR	01 Oct to 31 Oct	00:00 to 24:00	NA	NA		NA		0	
NER-ER	01 Oct to 31 Oct	00:00 to 07:00	3475	60	3415	258	3157	0	
		07:00 to 12:00	3480	60	3420	258	3162	0	
		12:00 to 18:00	3430	60	3370	258	3112	0	
		18:00 to 22:00	3350	60	3290	258	3032	0	
		22:00 to 24:00	3475	60	3415	258	3157	0	
NR-ER	01 Oct to 31 Oct	00:00 to 06:00	4000	300	3700	125	3575	0	
		06:00 to 18:00	4000	300	3700	1990	1710	0	
		18:00 to 24:00	4000	300	3700	125	3575	0	
NR-WR	01 Oct to	00:00 to 06:00	4000	500	3500	1267	2233	0	

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment	
	31 Oct	06:00 to 18:00	4000	500	3500	5177	0	0		
		18:00 to 24:00	4000	500	3500	1267	2233	0		
SR-ER	01 Oct to 31 Oct	00:00 to 24:00	No limit is being specified.							
SR-WR	01 Oct to 31 Oct	00:00 to 06:00	6000	650	5350	650	4700	-1400	TTC/ATC revised due to change in LGB and network augmentation	
		06:00 to 18:00	7650	650	7000	850	6150	250		
		18:00 to 24:00	6000	650	5350	650	4700	-1400		
W3 Injection	01 Oct to 31 Oct	00:00 to 24:00	NA	NA		NA		0		
W3-ER	01 Oct to 31 Oct	00:00 to 24:00	No limit is being specified.							
WR-ER	01 Oct to 31 Oct	00:00 to 06:00	5500	300	5200	990	4210	0		
		06:00 to 18:00	5500	300	5200	1040	4160	0		
		18:00 to 24:00	5500	300	5200	990	4210	0		
WR-NR	01 Oct to 31 Oct	00:00 to 06:00	17800	1000	16800	11476	5324	0		
		06:00 to 18:00	17800	1000	16800	11800	5000	0		
		18:00 to 24:00	17800	1000	16800	11476	5324	0		
WR-SR	01 Oct to 31 Oct	00:00 to 06:00	11600	650	10950	3685	7265	0		
		06:00 to 18:00	11600	650	10950	4787	6163	0		
		18:00 to 24:00	11600	650	10950	3685	7265	0		

- Based on the actual distribution of corridor flows, Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) NTPC Korba I, II

- & III, j) NTPC Sipat I & II, k) KSK Mahanadi, L)DB Power, m) REGL (Previously KWPCPL), m)RKM, o)REL, p) Bharat Aluminium, q)MCCPL, r)SKS, s) TRN, t)NTPC Lara, u) Adani Power Limited Raipur and any other regional entity generator in Chhattisgarh
- The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.
 - In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
 - Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

Simultaneous Import Capability

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
ER	01 Oct to 31 Oct	00:00 to 24:00	NA	NA		NA		0	
NER	01 Oct to 31 Oct	00:00 to 07:00	800	60	740	455	285	0	
		07:00 to 12:00	805	60	745	455	290	0	
		12:00 to 18:00	780	60	720	455	265	0	
		18:00 to 22:00	765	60	705	455	250	0	
		22:00 to 24:00	800	60	740	455	285	0	
NR	01 Oct to 31 Oct	00:00 to 06:00	25800	1400	24400	16573	7827	0	
		06:00 to 18:00	25800	1400	24400	16897	7503	0	
		18:00 to 24:00	25800	1400	24400	16573	7827	0	
SR	01 Oct to 31 Oct	00:00 to 06:00	17300	1000	16300	6763	9537	0	
		06:00 to 18:00	17300	1000	16300	7930	8370	0	
		18:00 to 24:00	17300	1000	16300	6763	9537	0	
WR	01 Oct to 31 Oct	00:00 to 24:00	NA	NA			0	0	

- Based on the actual distribution of corridor flows, Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) NTPC Korba I, II & III, j) NTPC Sipat I & II, k) KSK Mahanadi, L)DB Power, m) REGL (Previously KWPCPL), m)RKM, o)REL, p) Bharat Aluminium, q)MCCPL, r)SKS, s) TRN, t)NTPC Lara, u) Adani Power Limited Raipur and any other regional entity generator in Chhattisgarh
- The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would

factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

Simultaneous Export Capability

Corridor	Date	Time Period(hrs)	Total Transfer Capability(TTC)	Reliability Margin(RM)	Available Transfer Capability(ATC)	Long Term Access(LTA)/Medium Term Open Access(MTOA)	Margin Available For Short Term Open Access(STOA)	Chnages w.r.t. Previous Revision	Comment
ER	01 Oct to 31 Oct	00:00 to 24:00	NA	NA		NA		0	
NER	01 Oct to 31 Oct	00:00 to 07:00	3475	60	3415	258	3157	0	
		07:00 to 12:00	3480	60	3420	258	3162	0	
		12:00 to 18:00	3430	60	3370	258	3112	0	
		18:00 to 22:00	3350	60	3290	258	3032	0	
		22:00 to 24:00	3475	60	3415	258	3157	0	
NR	01 Oct to 31 Oct	00:00 to 06:00	4000	500	3500	1391	2109	0	
		06:00 to 18:00	4000	500	3500	7167	0	0	
		18:00 to 24:00	4000	500	3500	1391	2109	0	
SR	01 Oct to 31 Oct	00:00 to 06:00	5150	650	4500	2018	2482	-1200	TTC/ATC revised due to change in LGB and network augmentation
		06:00 to 18:00	6600	650	5950	2369	3581	250	
		18:00 to 24:00	5150	650	4500	2018	2482	-1200	
WR	01 Oct to 31 Oct	00:00 to 24:00	NA	NA		NA		0	

- Based on the actual distribution of corridor flows, Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for short-term transactions wherever applicable.
- Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.
- S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- W3 comprises of the following regional entities : a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) NTPC Korba I, II & III, j) NTPC Sipat I & II, k) KSK Mahanadi, l) DB Power, m) REGL (Previously KWPC), n) RKM, o) REL, p) Bharat Aluminium, q) MCCPL, r) SKS, s) TRN, t) NTPC Lara, u) Adani Power Limited Raipur and any other regional entity generator in Chhattisgarh
- The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would

factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

- In case of TTC Revision due to any shutdown : 1) The TTC value will be revised to normal values after restoration of shutdown. 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.
- Real Time TTC/ATC revisions are uploaded on Grid-India/NLDC "News Update" (Flasher) Section

Limiting Constraints

Corridor	Constraints	Revisions
WR-NR	N-1 contingency of one ckt of 765 kV Vindhyaachal-Varanasi will overload the other circuit	0-4
NR-ER	1. Overloading of one circuit of 400 kV New Ranchi – New PPSP D/C on the tripping of the other circuit 2. Overloading of one circuit of 400 kV Kahalgaon – Farakka D/C on the tripping of the other circuit 3. Overloading of 400 kV Farakka –Sagardighi – 1 on the tripping of 400 kV Farakka – Sagardighi - 2	0-4
WR-ER	1. Overloading of one circuit of 400 kV New Ranchi – New PPSP D/C on the tripping of the other circuit 2. Overloading of one circuit of 400 kV Kahalgaon – Farakka D/C on the tripping of the other circuit 3. Overloading of 400 kV Farakka –Sagardighi – 1 on the tripping of 400 kV Farakka – Sagardighi - 2	0-4
ER-NR	Inter-regional flow pattern towards NR	0-4
WR-SR	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	0-4
ER-SR	Low Voltage at Gazuwaka (East) Bus.	0-4
SR-WR	a) Angular separati on between Kudgi & Kolhapur (PG) under N-1 of 400 kV Kudgi - Kolhapur (PG) D/C touches 30 deg b) N-1 non-compliance of 2*1500 MVA, 765/400 kV ICTs at Secti on– A at Raigarh - PS(Kotra) with increase in HVDC Raigarh – Pugalur Bipole – II power order beyond 950 MW in SR to WRDirecti on (Solar Hours) c) N-1 non-compliance of 2*1500 MVA, 765/400 kV ICTs at Secti on– B at Raigarh -PS (Kotra) with increase in HVDC Raigarh – Pugalur Bipole – I power order beyond 450 MW in SR to WRDirecti on (Solar Hours) d) N-1 Conti ngency of 400 kV Pune – Kalwa will overload 400 kV Pune -Khargar &and vice-versa	3-4
ER-NER	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - Agia D/C	0-4
NER-ER	a) N-1 contingency of 220 kV Salakati - BTPS I or II b) High Loading of 220 kV Salakati - BTPS II or I	0-4
NR_IMPORT	N-1 contingency of one ckt of 765 kV Vindhyaachal-Varanasi will overload the other circuit	0-4
NR_EXPORT	(N-1) Contingency of 400 kV Kankroli-Zerda-S/C will overload 400 KV Bhinmal-Zerda-S/C	0-4
NER_IMPORT	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - Agia D/C	0-4
NER_EXPORT	a) N-1 contingency of 220 kV Salakati - BTPS I or II b) High Loading of 220 kV Salakati - BTPS II or I	0-4
SR_IMPORT	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT Low Voltage at Gazuwaka (East) Bus	0-4
SR_EXPORT	a) Angular separati on between Kudgi & Kolhapur (PG) under N-1 of 400 kV Kudgi - Kolhapur (PG) D/C touches 30 deg b) N-1 non-compliance of 2*1500 MVA, 765/400 kV ICTs at Secti on– A at Raigarh - PS(Kotra) with increase in HVDC Raigarh – Pugalur Bipole – II power order beyond 950 MW in SR to WRDirecti on (Solar Hours) c) N-1 non-compliance of 2*1500 MVA, 765/400 kV ICTs at Secti on– B at Raigarh -PS (Kotra) with increase in HVDC Raigarh – Pugalur Bipole – I power order beyond 450 MW in SR to WRDirecti on (Solar Hours) d) N-1 Conti ngency of 400 kV Pune – Kalwa will overload 400 kV Pune -Khargar &and vice-versa	3-4

Revision Summary

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
0	28 Jun			
1	28 Jul	01 Oct to 31 Oct	Revised STOA margin due to, 1. Operationalization of LTA of 225 MW from TPGEL_BKN to TPC MSEB 2. Operationalization of MTOA of 300 MW from TPGEL_BKN to TPC MSEB. 3. Operationalization of MTOA of 200 MW from ABCREPL_BHDL2 to MPSEB_Beneficiary. 4. Operationalization of MTOA of 100 MW from ABCREPL_BHDL2 to PONDY. 5. Increase in allocation quantum from Unchar-I to Gujarat by 36 MW 6. Decrease in the allocation quantum by 36 MW from Tanda-II to Gujarat. 7. Termination of allocation quantum of 5 MW from Meja TPS to Madhya Pradesh.	NR-WR
		01 Oct to 31 Oct	Revised STOA margin due to, 1. Operationalization of LTA of 1850 MW from MBMP to HARYANA. 2. Operationalization of MTOA of 61.5 MW from JPL-2 to NCRALL. 3. Increase in the LTA quantum by 41.8 MW from NETRA_KOTDA_BHUJ_W to HARYANA 4. Increase in the LTA quantum by 58.3 MW from Torrent_Sidpur_Jam_W to HARYANA	WR-NR

Revision	Date Of Revision	Period Of Revision	Reason for Revision/Comment	Corridor Affected
		01 Oct to 31 Oct	Revised STOA margin due to Increase in the LTA quantum by 52.5 MW from From Marwa Thermal Power Western Region to TGTRANSCO.	WR-SR
		01 Oct to 31 Oct	Revised STOA margin due to operationalisation of new allocation of 5 MW from BRBCL to Assam.	ER-NER
		01 Oct to 31 Oct	Revised STOA margin due to discontinuation of allocation quantum of 140.4 MW from BgTPP to Tamil Nadu	NER-ER
		01 Oct to 31 Oct	Revised STOA margin due to, 1. Operationalization of LTA of 1850 MW from MBMP to HARYANA. 2. Operationalization of MTOA of 61.5 MW from JPL-2 to NCRALL. 3. Increase in the LTA quantum by 41.8 MW from NETRA_KOTDA_BHUJ_W to HARYANA 4. Increase in the LTA quantum by 58.3 MW from Torrent_Sidpur_Jam_W to HARYANA	NR_IMPORT
		01 Oct to 31 Oct	Revised STOA margin due to operationalisation of new allocation of 5 MW from BRBCL to Assam.	NER_IMPORT
		01 Oct to 31 Oct	Revised STOA margin due to Increase in the LTA quantum by 52.5 MW from From Marwa Thermal Power Western Region to TGTRANSCO.	SR_IMPORT
		01 Oct to 31 Oct	Revised STOA margin due to, 1. Operationalization of LTA of 225 MW from TPGEL_BKN to TPC MSEB 2. Operationalization of MTOA of 300 MW from TPGEL_BKN to TPC MSEB. 3. Operationalization of MTOA of 200 MW from ABCREPL_BHDL2 to MPSEB_Beneficiary. 4. Operationalization of MTOA of 100 MW from ABCREPL_BHDL2 to PONDY. 5. Increase in allocation quantum from Unchahar-I to Gujarat by 36 MW 6. Decrease in the allocation quantum by 36 MW from Tanda-II to Gujarat. 7. Termination of allocation quantum of 5 MW from Meja TPS to Madhya Pradesh.	NR_EXPORT
		01 Oct to 31 Oct	Revised STOA margin due to discontinuation of allocation quantum of 140.4 MW from BgTPP to Tamil Nadu	NER_EXPORT
2	28 Aug	01 Oct to 31 Oct	Change in STOA margin due to increase in the LTA quantum by 24.7 MW from NETRA_KOTDA_BHUJ_W to Haryana	WR-NR
		01 Oct to 31 Oct	Change in STOA margin due to increase in the LTA quantum by 24.7 MW from NETRA_KOTDA_BHUJ_W to Haryana	NR_IMPORT
3	28 Aug	01 Oct to 31 Oct	Change in STOA margin due to increase in the LTA quantum by 24.7 MW from NETRA_KOTDA_BHUJ_W to Haryana	WR-NR
		01 Oct to 31 Oct	Change in STOA margin due to increase in the LTA quantum by 24.7 MW from NETRA_KOTDA_BHUJ_W to Haryana	NR_IMPORT
4	19 Sep	01 Oct to 31 Oct	TTC/ATC revised due to change in LGB and network augmentation	SR-WR
		01 Oct to 31 Oct	TTC/ATC revised due to change in LGB and network augmentation	SR_EXPORT

BASECASE LGBR					
S.No.	Name of State/Region	Load		Month:	Oct'23
		Peak Load (MW)	Off Peak Load (MW)	Generation	
				Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	6187	4320	4431	2467
2	Haryana	6301	4633	2327	2029
3	Rajasthan	14634	8276	8964	6149
4	Delhi	4138	1632	530	506
5	Uttar Pradesh	15439	10852	10732	7505
6	Uttarakhand	1894	1473	383	297
7	Himachal Pradesh	1707	1017	546	240
8	Jammu & Kashmir	2488	2157	236	227
9	Chandigarh	197	89	0	0
10	ISGS/IPPs	53	52	21207	9340
	Total NR	53038	34501	49356	28761
II	EASTERN REGION				
1	Bihar	4303	3220	484	409

2	Jharkhand	1498	1268	436	409
3	Damodar Valley Corporation	3224	3002	5182	4218
4	Odisha	5447	4870	3217	2628
5	West Bengal	5848	4471	5542	4582
6	Sikkim	103	55	0	0
7	Bhutan	57	56	107	68
8	ISGS/IPPs	748	698	14253	11518
	Total ER	21230	17642	29221	23833
III	WESTERN REGION				
1	Maharashtra	24497	17173	16678	12825
2	Gujarat	18565	15139	8330	8534
3	Madhya Pradesh	15672	9581	6140	4836
4	Chattisgarh	4723	3510	2439	2625
5	Daman and Diu	0	0	0	0
6	Dadra and Nagar Haveli	903	910	0	0
7	Goa-WR	538	427	0	0
8	ISGS/IPPs	5326	4186	46483	31327
	Total WR	70222	50926	80070	60147
IV	SOUTHERN REGION				
1	Andhra Pradesh	10976	7444	6488	4721
2	Telangana	12210	9955	7160	4955
3	Karnataka	13204	8407	7228	5718
4	Tamil Nadu	16464	13330	9475	5630
5	Kerala	3474	3023	1037	583
6	Pondy	385	377	0	0
7	Goa-SR	90	88	0	0
8	ISGS/IPPs	0	0	19219	15358
	Total SR	56804	42625	50606	36964
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	123	94	7	7
2	Assam	1193	1068	289	292
3	Manipur	188	118	0	0
4	Meghalaya	367	288	100	24
5	Mizoram	92	63	33	54
6	Nagaland	160	162	18	17
7	Tripura	214	229	164	159
8	ISGS/IPPs	0	0	2248	2153
	Total NER	2338	2022	2859	2707
	Total All India	203632	147716	212112	152412