

**National Load Despatch Centre
Total Transfer Capability for September 2013**

Issue Date: 24/06/2013

Issue Time: 1500 hrs

Revision No. 3

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR	1st September 2013 to 30th September 2013	00-24	2500	500	2000	286	1714		
WR-NR ¹	1st September 2013 to 30th September 2013	00-17	5700 ^Δ	500	5200 ^Δ	2787 ^Δ	2413		
		23-24	5500 ^Δ		5000 ^Δ	2787 ^Δ	2213		
NR-ER	1st September 2013 to 30th September 2013	00-17	1000	200	800	0	800		
		23-24	1100		900		900		
ER-NR	1st September 2013 to 30th September 2013	00-17	4000	300	3700	2189	1511		
		23-24					1511		
W3-ER	1st September 2013 to 30th September 2013	00-24	1900	300	1600	0	1600		
ER-W3	1st September 2013 to 30th September 2013	00-24	1000	300	700	650	50		
WR-SR	1st September 2013 to 30th September 2013	00-24	1000	0	1000	1000	0		
SR-WR	1st September 2013 to 30th September 2013	00-24	1000	0	1000	0	1000		
ER-SR	1st September 2013 to 30th September 2013	00-05	1100	0	1100	612	488		
		10-19	1100		1100		488		
SR-ER	1st September 2013 to 30th September 2013	00-17	800	0	800	197	603		
		23-24	900		900		703		
ER-NER	1st September 2013 to 30th September 2013	00-17	600	35	565	230	335		
		23-24	600		565		335		
NER-ER	1st September 2013 to 30th September 2013	00-17	500	100	400	0	400		
		23-24	320		220		220		
S1-S2	1st September 2013 to 30th September 2013	00-24	5800	200	5600	5200	400		
Import of Punjab #	1st September 2013 to 30th September 2013	00-24	5600	300	5300	3475	1825		Revised due to change LTA/MTOA quantum.
Import TTC for DD & DNH	1st September 2013 to 30th September 2013	00-24	980	0	980	LTA and MTOA as per ex-pp schedule			
W3 zone Injection	1st September 2013 to 30th September 2013	00-17,	9000	200	8800	7630	1170		
		23-24	9500		9300		1670		

1) ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam

2) S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry

3) W3 comprises of the following regional entities :

a) Chattisgarh, b) Jindal Power Limited (JPL) , c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak

f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat

**National Load Despatch Centre
Total Transfer Capability for September 2013**

Issue Date: 24/06/2013

Issue Time: 1500 hrs

Revision No. 3

Δ. includes 1500 MW on the dedicated Mundra-Mohindergarh HVDC bipole of M/s Adani Power Limited which is scheduled separately from the generation at stage-III of APL Mundra (3*660 MW).

I. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:

- 765 kV Agra-Jhatikara
- One of the 765/400 kV 1500 MVA ICT at Agra
- 765 kV Gwalior-Agra one circuit
- 765 kV Bina-Gwalior one circuit

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.
WR-NR	(n-1) contingency of 765/400 kV ICT at Agra
NR-ER	(n-1) contingency of 400 kV Allahabad-Pusauli
ER-NR	(n-1) contingency of 400 kV Purnea-Muzaffarpur
W3-ER	(n-1) contingency of either 400 kv Mejia-Maithon or (n-1) contingency of 400 kv MPL -Maithon
ER-W3	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni* (n-1) contingency of 400kV Rourkela-Raigarh
WR-SR	Bhadrawati HVDC B/B link capacity
SR-WR	Bhadrawati HVDC B/B link capacity
ER-SR	(n-1) contingency of 400 kV Rourkela-Talcher*
SR-ER	
ER-NER	(n-1) contingency of 400/220 kV,315 MVA ICT at Misa* (n-1) contingency of 400 kV Binaguri-Bongaigaon
NER-ER	High loading of 132 kV LTPS – Mariani S/C Insufficient generating resources in NER
S1-S2	(n-1) contingency of 400 kV Kolar-Hosur D/C line, 400kV Hosur-Salem S/C and 400kV Somanahalli-Salem S/C line.
Import of Punjab	(n-1) contingency of ICT at Patiala/Moga
W3 zone Injection	(n-1-1) contingency of 400 kV Raipur-Bhadrawati D/C section

*Primary constraints

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR ¹	1st September 2013 to 30th September 2013	00-17 23-24	9700 ^Δ	1000	8700 ^Δ	4976 ^Δ	3724		
		17-23	9500 ^Δ		8500 ^Δ		3524		
NER	1st September 2013 to 30th September 2013	00-17 23-24	600	35	565	230	335		
		17-23	600		565		335		
WR									
SR	1st September 2013 to 30th September 2013	00-05	2100	0	2100	1612	488		
		10-19							
		05-10	2100		2100		488		
		19-24							

Δ. includes 1500 MW on the dedicated Mundra-Mohindergarh HVDC bipole of M/s Adani Power Limited which is scheduled separately from the generation at stage-III of APL Mundra (3*660 MW).

I. WR-NR Total Transfer capability will be reduced to 3100 MW in case of outage of any one of the following sections:

- 765 kV Agra-Jhatikara
- One of the 765/400 kV 1500 MVA ICT at Agra
- 765 kV Gwalior-Agra one circuit
- 765 kV Bina-Gwalior one circuit

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR	1st September 2013 to 30th September 2013	00-17 23-24	3500	700	2800	286	2514		
		17-23	3600		2900		2614		
NER	1st September 2013 to 30th September 2013	00-17 23-24	500	100	400	0	400		
		17-23	320		220		220		
WR									
SR	1st September 2013 to 30th September 2013	00-17 23-24	1800	0	1800	197	1603		
		17-23	1900		1900		1703		

Limiting Constraints

NR	Import	(n-1) contingency of 400 kV Purnea-Muzaffarpur* (n-1) contingency of 765/400 kV ICT at Agra
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Allahabad-Pusauli
NER	Import	(n-1) contingency of 400/220 kV,315 MVA ICT at Misa* (n-1) contingency of 400 kV Binaguri-Bongaigaon
	Export	High loading of 132 kV LTPS – Mariani S/C Insufficient generating resources in NER
SR	Import	Bhadrawati HVDC B/B link capacity (n-1) contingency of 400 kV Rourkela-Talcher*
	Export	Bhadrawati HVDC B/B link capacity

*Primary constraints

ASSUMPTIONS IN BASECASE

Month : September '13

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7253	6913	2728	2423
2	Haryana	6245	5828	3512	3512
3	Rajasthan	6749	6004	3624	3616
4	Delhi	4432	3910	1276	1276
5	Uttar Pradesh	11080	12540	4345	4134
6	Jammu & Kashmir	1994	1050	617	640
7	Uttarakhand	1602	1536	775	775
8	Himachal Pradesh	1511	1000	955	975
9	Chandigarh	279	193	0	0
10	ISGS/IPPs			18230	15865
	Total NR	41145	38974	36062	33216
II	EASTERN REGION				
1	West Bengal	6980	5310	4769	4094
2	Jharkhand	1045	660	544	354
3	Orissa	3630	2750	2889	2149
4	Bihar	1870	1320	0	0
5	Damodar Valley Corporation	2500	1980	3219	3219
6	Sikkim	40	40	0	0
7	Bhutan	111	111	1356	1356
8	ISGS/IPPs	21	21	5956	5956
	Total ER	16197	12192	18733	17128
III	WESTERN REGION				
1	Chattisgarh	2846	2482	1373	2154
2	Madhya Pradesh	7700	5038	3908	2659
3	Maharashtra	14190	12362	9196	6579
4	Gujarat	10859	8313	10508	7908
5	Goa	398	238	0	0
6	Daman and Diu	234	206	0	0
7	Dadra and Nagar Haveli	571	553	0	0
8	ISGS/IPPs	590	592	16956	14488
	Total WR	37388	29784	41941	33788

ASSUMPTIONS IN BASECASE

Month : September '13

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	10964	8914	7317	5430
2	Tamil Nadu	10755	9192	6765	5051
3	Karnataka	7831	5859	5033	3582
4	Kerala	3289	2424	1892	1073
5	Pondy	314	243	0	0
6	Goa	80	80	0	0
7	ISGS/IPPs			10476	9895
	Total SR	33233	26712	31483	25031
V	NORTH-EASTERN REGION				
1	Manipur	130	91	0	0
2	Meghalaya	280	196	148	68
3	Mizoram	85	60	8	6
4	Nagaland	120	84	12	10
5	Assam	1415	970	240	200
6	Tripura	230	130	100	80
7	Arunachal Pradesh	130	91	0	0
8	ISGS/IPPs			1297	1080
	Total NER	2390	1622	1805	1444
	Total All India	130353	109284	130024	110607