Issue Date: 4th September 2020 Issue Time: 1800 hrs Revision No. 3

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st September	00-06				195	1805		
NR-WR*	2020 to 30th September	06-18	2500	500	2000	1281	719		
	2020	18-24				195	1805		
		00-06	18150 17200**	500	17650 16700**	10268 9318**	7382		
WR-NR*	1st September 2020 to 30th September	06-18	18150 17200**	500	17650 16700**	10657 9707**	6993		_
	2020	18-24	18150 17200**	500	17650	10268	7382		_
	1st September	00-06	2000		1800	193	1607		
NR-ER*	2020 to 30th	06-18	2000	200	1800	303	1497		
ER-NR*	September 1st September 2020 to 30th September 2020	00-24	6250	300	1800 5950	193 4066	1884		
W3-ER ER-W3	1st September 2020 to 30th September 2020 1st September 2020 to 30th September	00-24					s being specified. s being specified.		
	2020								
WR-SR [^]	1st September 2020 to 5th	00-05	6950 6950	500	6450 6450	4049	2401 2401		
WR-SR [^]	September 6th September 2020	22-24 00-05 05-09 09-22 22-24	6950 6950 6950 6100	500	6450 6450 6950 5600	4049	2401 2401 6950 1551 1551	-850 -850	Revision in TTC/ATC due to planned outage of 765 kV Raichur Solapur-I
WR-SR [^]	7th September 2020 to 30th September	00-05 05-22 22-24	6950 6950 6950	500	6450 6950 6450	4049	2401 6950 2401	050	_
SR-WR*	1st September 2020 to 30th September 2020	00-24	4600	400	4200	550	3650		
	1st September 2020 to 5th	00-06				2663	3037		_
ER-SR [^]	September	06-18	5950	250	5700	2748	2952		_
	2020	18-24				2663	3037		
			5950		5700	2663	3037		
		00-06							Pavision in TTC/ATC due to
ER-SR [△]	6th September	06-09	5950	250	5700	2748	2952		Revision in TTC/ATC due to planned outage of 765 kV Raichur
ER-SR [^]	6th September 2020		5950 5850	250	5600	2748 2748	2952 2852	-100	
ER-SR [△]		06-09	5950	250				-100 -100	planned outage of 765 kV Raichur
ER-SR [△]	2020 7th September	06-09 09-18	5950 5850	250	5600	2748	2852		planned outage of 765 kV Raichur -
ER-SR [^]	2020	06-09 09-18 18-24	5950 5850	250	5600	2748 2663	2852 2937		planned outage of 765 kV Raichur -

Issue Date: 4th September 2020 Issue Time: 1800 hrs Revision No. 3

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
SR-ER *	1st September 2020 to 30th September 2020	00-24	No limit is being Specified.							
		00-02	1750		1705	474	1231			
		02-07	1750		1705	474	1231			
	1 . 0 1	07-12	1750		1705	474	1231			
ER-NER*	1st September 2020 to 30th	12-17	1750	15	1705	474	1231			
EK-NEK*	September 2020	17-18	1750	45	1705	474	1231			
		18-22	1620		1575	474	1101			
		22-23	1750		1705	474	1231			
		23-24	1750		1705	474	1231			
		00-02	1820		1775	42	1733			
		02-07	1820		1775	42	1733			
		02-07	1820		1775	42	1733			
	1st September	07-12	1820		1775	42	1733			
NER-ER*	2020 to 30th September	12-17	1820	45	1775	42	1733			
	2020	17-18	1820		1775	42	1733			
		18-22	1910		1865	42	1823			
		22-23	1820		1775	42	1733			
		23-24	1820		1775	42	1733			
W3 zone Injection	1st September 2020 to 30th September 2020	00-24	No limit is be	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)						

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

- 1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n) Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis.

In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

^{**}Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

Issue Date: 4th September 2020 Issue Time: 1800 hrs Revision No. 3

Corridor	Date Perio	iod Transfer Canability	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------------	----------------------------------	-----------------------	--	--	--	-------------------------------------	----------

[^]Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropriate measures.

SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00.06	24400		23600	14334	0266		
		00-06	23450**		22650**	13384**	9266		
			24400		23600	14723			1
		06-09	24400		23000	14/23	8877		
		00-07	23450**		22650**	13773**	0077		
	1st September		24400		23600	14723			
\mathbf{NR}^*	2020 to 30th	09-17		800			8877		
	September 2020		23450**		22650**	13773**			
			24400		23600	14723			
		17-18					8877		
			23450**		22650**	13773**			
		18-24	24400		23600	14334	9266		

			23450**		22650**	13384**			
		00-02	1050	45	1005	474	531		
		02-07	1050		1005	474	531		
		07-12	1050		1005	474	531		
NED*	1st September 2020 to 30th	12-17	1050		1005	474	531		
NER*	September 2020	17-18	1050		1005	474	531		
		18-22	920		875	474	401		
		22-23	1050		1005	474	531		
		23-24	1050		1005	474	531		
\mathbf{WR}^*									
	1st Contombor	00-06	12900		12150	6712	5438		
SR*#	1st September 2020 to 5th	06-18	12900	750	12150	6797	5353		
SI	September 2020	18-24	12900	750	12150	6712	5438		
	zeptemoer 2020	00-06	12900		12150	6712	5438		
a *#	6th September	06-09	12900	7.50	12150	6797	5353		Revision in TTC/ATC due to
$\mathbf{SR}^{*\#}$	2020	09-18	11950	750	11200	6797	4403	-950	planned outage of 765 kV
		18-24	11950		11200	6712	4488	-950	Raichur - Solapur-I
	7th September	00-06	12900		12150	6712	5438		
$\mathbf{SR}^{*\#}$	2020 to 30th	06-18	12900	750	12150	6797	5353		
	September 2020	18-24	12900		12150	6712	5438		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

^{**}Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NR ATC = C

Margin for WR-NR applicants = A * B/(B+C)

Margin for ER-NR Applicants = A * C/(B+C)

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Simultan	Simultaneous Export Capability												
Corrido r	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments				
	1st September	00-06	4500		3800	388	3412						
NR*	2020 to 30th	06-18		700	3800	1584	2216						
	September 2020	18-24	4500		3800	388	3412						
		00-02	2520	45	2475	42	2433						
		02-07	2520		2475	42	2433						
	1 . 0 . 1	07-12	2520		2475	42	2433						
NED*	1st September	12-17	2520		2475	42	2433						
NER*	2020 to 30th	17-18	2520		2475	42	2433						
	September 2020	18-22	2610		2565	42	2523						
		22-23	2520		2475	42	2433						
		23-24	2520		2475	42	2433						
WD*													
WR*													
SR*^	1st September 2020 to 30th September 2020	00-24	3700	400	3300	1150	2150						

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

Limiting	Constraints (Corridor wise)	
		Applicable Revisions
Corridor	Constraint	
WR-NR	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev 0 to 3
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev 0 to 3
ER-NR	 N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. Inter-regional flow pattern towards NR 	Rev 0 to 3
WR-SR	n-1 contingency of one ckt of 765 kV Wardha - Nizamabad D/C will overload of the other ckt	
	n-1 contingency of one ckt of 765 kV Angul - Srikakulam D/C will overload of the other ckt	Rev 0 to 3
SK	Low Voltage at Gazuwaka (East) Bus.	
SR-WR	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev 0 to 3
ER-NER	 a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C 	Rev 0 to 3
NER-ER	 a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading of 400 kV Silchar-Killing Line 	Rev 0 to 3
W3 zone Injection		Rev 0 to 3

Limiting Constraints (Simultaneous)

		(Diffutureous)	Applicable Revisions
NR	Import	 N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. Inter-regional flow pattern towards NR 	Rev 0 to 3
INIX		N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev 0 to 3
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	Rev 0 to 3
	Export	(n-1) contingency of 400 kV Saranath-Pusauli	
NER	Import	 a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C 	Rev 0 to 3
NEK	Export	a) N-1 contingency of 400 kV Silchar- Azara lineb) High Loading of 400 kV Silchar-Killing Line	Rev 0 to 3
		n-1 contingency of one ckt of 765 kV Wardha - Nizamabad D/C will overload of the other ckt	Rev 0 to 3
	Import	n-1 contingency of one ckt of 765 kV Angul - Srikakulam D/C will overload of the other ckt	
		Low Voltage at Gazuwaka (East) Bus	
SR		N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt	Rev 0 to 3
	Export	N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	

Revision	Date of	Period of	Reason for Revision/Comment	Corridor
No	Revision	Revision	Reason for Revision/Comment	Affected
			Revision in STOA margin due to change in LTA quantum from GIWEL_SECI-III_RE (Wind, Bhuj) to Punjab from 151.2 MW to 200 MW	WR-NR/Import of NR
1	28th June 2020	Whole Month	Revision in STOA margin due to allocation of 20.75 MW power from Kameng HEP to UP, Haryana, Chhattisgarh and Goa	NER-ER/Export of NER/ER- NR/Import of NR
2	30th August 2020	Whole Month	Revision in TTC/ATC due to the following:- a) Change in Load-Generation of NER b) Addition of 2x150 MW out of 4 x 150 MW Kameng Generation c) Incorporation of HVDC flow of 700 MW between Biswanath Chariali and Agra Revision in STOA margin due to the following:- a) Increase in allocation from Kameng HEP to UP, Haryana, Chhattisgarh and Goa b) Revision in LTA/allocation from GIWEL, Bhuj (Wind) and Mangdechu HEP to Assam	ER-NER/NER- ER/Import and Export of NER
			Revision in TTC/ATC due to:- a) Commissioning of HVDC Champa - Kurukshetra Pole-4 b) Change in HVDC APD-Agra power order and load- generation balance.	WR-NR/ER- NR/Import of NR
3	4th Sep 2020	6th Sep 2020	Revision in TTC/ATC due to planned outage of 765 kV Raichur - Solapur-I	ER-SR/WR- SR/Import of SR

ASSUN	MPTIONS IN BASECASE				
				Month : September'20	20
S.No.	Name of State/Area		Load	Genera	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	10228	9530	4580	4618
2	Haryana	9146	9428	2953	2953
3	Rajasthan	10205	11428	6168	6168
4	Delhi	5674	6558	753	753
5	Uttar Pradesh	18102	15529	9903	9908
6	Uttarakhand	2144	1981	1060	1015
7	Himachal Pradesh	1562	1558	859	854
8	Jammu & Kashmir	3049	1686	1075	1017
9	Chandigarh	375	303	0	0
10	ISGS/IPPs	23	23	20932	19626
	Total NR	60510	58023	48283	46912
II	EASTERN REGION				
1	Bihar	5380	4412	99	110
2	Jharkhand	1637	1024	425	421
3	Damodar Valley Corporation	3028	2466	4980	4180
4	Orissa	4823	3995	3952	2615
5	West Bengal	8541	7006	5659	4956
6	Sikkim	114	43	0	0
7	Bhutan	171	168	1474	1444
8	ISGS/IPPs	-171	-168	11907	10404
	Total ER	23523	18947	28495	24128
III	WESTERN REGION				
1	Maharashtra	16912	14197	12996	9886
2	Gujarat	13683	8433	10325	6208
3	Madhya Pradesh	8253	5455	4058	2863
4	Chattisgarh	3890	3168	2239	2230
5	Daman and Diu	297	153	0	0
6	Dadra and Nagar Haveli	781	550	0	0
7	Goa-WR	513	326	0	0
8	ISGS/IPPs	4640	3609	33397	25451
	Total WR	48969	35891	63015	46638

S.No.	Name of State/Area		Load	Gener	ation
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	9316	6695	6310	5934
2	Telangana	9937	9870	5913	4863
3	Karnataka	8351	4343	6606	3257
4	Tamil Nadu	14738	12867	8660	7460
5	Kerala	3683	2236	1649	423
6	Pondy	298	246	0	0
7	Goa-SR	58	48	0	0
8	ISGS/IPPs	0	0	14970	12179
	Total SR	46381	36305	44109	34117
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	111	70	18	16
2	Assam	1707	1346	295	245
3	Manipur	183	82	0	0
4	Meghalaya	269	198	237	142
5	Mizoram	99	66	68	42
6	Nagaland	120	75	22	16
7	Tripura	259	154	76	75
8	ISGS/IPPs	159	81	2385	2242
	Total NER	2907	2073	3101	2778
	Total All India	182131	151157	187003	154572