National Load Despatch Centre Total Transfer Capability for December 2017

Issue Date: 20th September 2017 Issue Time: 1800 hrs Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
	1st December	00-06				55	1945			
NR-WR*	2017 to 31st	06-18	2500	500	2000	65	1935			
	December 2017	18-24				55	1945			
WR-NR*	1st December 2017 to 31st December 2017	00-24	9050	500	8550	8330	220			
	1.15. 1	00.05	2000		1000	102	1.605	<u> </u>		
NR-ER*	1st December 2017 to 31st	00-06 06-18	2000 2000	200	1800 1800	193 303	1607 1497	-		
INK-LIK	December 2017	18-24	2000	200	1800	193	1607	1		
ER-NR*	1st December 2017 to 31st December 2017	00-24	4500	300	4200	3030	1170			
W3-ER	1st December 2017 to 31st December 2017	00-24				No limit i	s being specified.			
ER-W3	2017 to 31st	00-24				No limit i	s being specified.			
	1st December		00-05	4700		4200		717	350	Revised considering commissioning and commercial operation of 765 kV Nizamabad - Maheswaram D/C, 765/400 kV 2x1500 MVA ICTs at Maheswaram, 400 kV
WR-SR		2017 to 31st 05-22 4700 5	500	4200	3483	717	350	Maheswaram (PG) - Maheswaram D/C, 400/220 kV 1x500 MVA ICTs at Maheswaram, 400 kV		
		22-24	4700		4200		717	350	Maheswaram(PG) - Kurnool S/C and 400 kV Maheswaram - Ghanapur S/C (LILO of 400 kV Ghanapur - Kurnool S/C)	
SR-WR*	1st December 2017 to 31st December 2017	00-24				No limit is	s being Specified.			
		00-06				3053	447	300	Revised considering commissioning and commercial operation of 765 kV Nizamabad - Maheswaram D/C, 765/400 kV 2x1500 MVA ICTs at	
ER-SR	1st December 2017 to 31st December 2017	06-18'	3750	250	3500	3138	362	300	Maheswaram, 400 kV Maheswaram(PG) - Maheswaram D/C, 400/220 kV 1x500 MVA ICTs at Maheswaram, 400 kV	
		18-24				3053	447	300	Maheswaram(PG) - Kurnool S/C and 400 kV Maheswaram - Ghanapur S/C (LILO of 400 kV Ghanapur - Kurnool S/C)	
SR-ER *	1st December 2017 to 31st December 2017	00-24				No limit is	s being Specified.			

National Load Despatch Centre Total Transfer Capability for December 2017

Issue Date: 20th September 2017 Issue Time: 1800 hrs Revision No. 1

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1 of December	00.17	1270	Γ	1225		1000		
ED MED	1st December	00-17	1270	4.5	1225	225	1000	<u>.</u>	
ER-NER	2017 to 31st	17-23	1160	45	1115	225	890	<u>.</u>	
	December 2017	23-24	1270		1225		1000		
	1st December	00-17	1400		1355		1355		
NER-ER	2017 to 31st	17-23	1400	45	1355	0	1355		
	December 2017	23-24	1400		1355		1355	1	
W3 zone Injection	1 2017 to 31st 1 00-24 INo limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)								

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

- 1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
NR	1st December 2017 to 31st December 2017	00-05 05-08 08-18 18-23 23-24	12900 12900 12900 11300 12900	800	12100 12100 12100 10500 12100	11360	740 740 740 0 740		
NER	1st December 2017 to 31st December 2017	00-17 17-23 23-24	1270 1160 1270	45	1225 1115 1225	225	1000 890 1000		
WR									
		00-05	8450		7700	6536	1164	650	Revised considering commissioning and commercial operation of
		05-06	8450		7700	6536	1164	650	765 kV Nizamabad - Maheswaram D/C, 765/400 kV 2x1500 MVA
SR	1st December 2017 to 31st December 2017	06-18	8450	750	7700	6621	1079	650	ICTs at Maheswaram, 400 kV Maheswaram(PG) - Maheswaram D/C, 400/220 kV 1x500 MVA
		18-22	8450		7700	6536	1164	650	ICTs at Maheswaram, 400 kV Maheswaram(PG) - Kurnool S/C and 400 kV
		22-24	8450		7700	6536	1164	650	Maheswaram - Ghanapur S/C (LILO of 400 kV Ghanapur - Kurnool S/C)

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Margin in Simultaneous import of NR = A

WR-NR ATC =B ER-NR ATC = C

Margin for WR-NR applicants = A * B/(B+C)Margin for ER-NR Applicants = A * C/(B+C)

^{*} For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st December	00-06	4500		3800	248	3552		
NR*	2017 to 31st	06-18		700	3800	368	3432		
	December 2017	18-24	4500		3800	248	3552		
	1st December	00-17	1400		1355		1355		
NER	2017 to 31st	17-23	1400	45	1355	0	1355		
	December 2017	23-24	1400		1355		1355		
WR									
SR*	1st December 2017 to 31st December 2017	00-24		No limit is being Specified.					

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints (Corridor wise)

		Applicable Revisions
Corridor	Constraint	
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak	All
WR-NR	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2. High Loading of 400kV Singrauli-Anpara S/C.	All
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	All
ER-NR	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c	All
WR-SR	(n-1) contingency of 400 kV Dichipalli-Ramagundam or one ckt of 765 kV Aurangabad-Solapur D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna S/C)	All
& ER- SR	 a. (n-1) contingency of 400 kV Vemagiri - Vijaywada S/C will lead to high loading (874 MW) on 400 kV Vemagiri - Gazuwaka S/C b. N-1 contingency of 765/400 kV 2x1500 MVA Maheswaram (PG) ICTs results in high loading of other ICT 	All except Rev-0
	Low Voltage at Gazuwaka (East) Bus.	All
ER-NER	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa b. High loading of 220 kV Balipara-Sonabil line(200 MW)	All
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of 220 kV Samaguri - Sonabil line	All
W3 zone Injection		All

Limiting Constraints (Simultaneous)

			Applicable Revisions
NR	Import	(n-1) contingencies of N.Ranchi - Chandawa S/c & (n-1) contingencies of 400kV MPL- Maithon S/c. 1. (n-1) Contingency of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit. 2. High Loading of 400kV Singrauli-Anpara S/C.	All
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	All
NER	Import	a. (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa High loading of 220 kV Balipara-Sonabil line(200 MW)	All
NEK	Export	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of 220 kV Samaguri - Sonabil line	All
		(n-1) contingency of 400 kV Dichipalli-Ramagundam or one ckt of 765 kV Aurangabad-Solapur D/C will lead to 874 MW loading on 400kV Vemagiri(PG)-Gazuwaka (With Opening of 400kV Vemagiri(PG)-Nunna S/C)	All
SR	Import	a. (n-1) contingency of 400 kV Vemagiri - Vijaywada S/C will lead to high loading (874 MW) on 400 kV Vemagiri - Gazuwaka S/C b. N-1 contingency of 765/400 kV 2x1500 MVA Maheswaram (PG) ICTs results in high loading of other ICT	All except Rev 0
		Low Voltage at Gazuwaka (East) Bus.	All

National Load Despatch Centre Total Transfer Capability for December 2017

Revision	Date of	Period of	Reason for Revision	Corridor
No	Revision	Revision		Affected
1	20th September 2017	Whole Month	Revised considering commissioning and commercial operation of 765 kV Nizamabad - Maheswaram D/C, 765/400 kV 2x1500 MVA ICTs at Maheswaram, 400 kV Maheswaram(PG) - Maheswaram D/C, 400/220 kV 1x500 MVA ICTs at Maheswaram, 400 kV Maheswaram(PG) - Kurnool S/C and 400 kV Maheswaram - Ghanapur S/C (LILO of 400 kV Ghanapur - Kurnool S/C)	ER-SR / WR- SR / Import of SR

ASSUN	MPTIONS IN BASECASE				
				Month: Nov'17	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	5076	3313	2505	2469
2	Haryana	6779	3330	1533	1533
3	Rajasthan	10005	10899	5097	5121
4	Delhi	3244	1750	755	755
5	Uttar Pradesh	15422	13884	8026	7851
6	Uttarakhand	1899	1518	848	390
7	Himachal Pradesh	1421	1282	195	85
8	Jammu & Kashmir	2496	2504	551	356
9	Chandigarh	175	91	0	0
10	ISGS/IPPs	26	26	17096	8611
	Total NR	46543	38599	36606	27171
Ш	EASTERN REGION				
1	Bihar	4062	2536	202	181
2	Jharkhand	1290	891	197	190
3	Damodar Valley Corporation	3068	2634	4868	3974
4	Orissa	4265	3347	3232	2292
5	West Bengal	7139	5869	5379	4539
6	Sikkim	88	50	0	0
7	Bhutan	212	216	1434	1434
8	ISGS/IPPs	267	263	11767	8535
	Total ER	20389	15807	27079	21146
III	WESTERN REGION				
1	Maharashtra	17837	13518	12629	10871
2	Gujarat	12982	10844	9406	8143
3	Madhya Pradesh	11007	8265	5273	4547
4	Chattisgarh	3620	2188	2520	1990
5	Daman and Diu	312	269	0	0
6	Dadra and Nagar Haveli	635	686	0	0
7	Goa-WR	570	316	0	0
8	ISGS/IPPs	3903	3510	34513	29450
	Total WR	50865	39597	64342	55002
		· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·		

IV	SOUTHERN REGION				
1	Andhra Pradesh	7515	6742	5781	3958
2	Telangana	7346	5433	4521	2775
3	Karnataka	10351	8454	5936	4350
4	Tamil Nadu	13800	11600	6869	5544
5	Kerala	3743	2200	1400	141
6	Pondy	387	387	0	0
7	Goa-SR	87	87	0	0
8	ISGS/IPPs	0	0	13456	12330
	Total SR	43229	34903	37963	29098
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	122	63	0	0
2	Assam	1057	825	230	140
3	Manipur	147	87	0	0
4	Meghalaya	307	203	145	82
5	Mizoram	89	65	8	8
6	Nagaland	97	81	8	6
7	Tripura	197	185	83	82
8	ISGS/IPPs	160	60	1677	1260
	Total NER	2176	1569	2151	1578
	Total All India	163444	130721	169633	135488