# National Load Despatch Centre Total Transfer Capability for September 2021

Issue Date: 17th July, 2021 Issue Time: 1730 hrs Revision No. 3

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st September 2021 to 30th	00-06				253	1747		
NR-WR*		06-18	2500	500	2000	1339	661		
	September 2021	18-24				253	1747		
			18450		17450	11010			
		00-06	17500**	1000	16500**	10060**	6440		
WR-NR*	1st September 2021 to 30th September 2021	06-18	18450 17500**	1000	17450 16500**	11399 10449**	6051		Revised Reliability Margin (TRM) from 500MW to 1000 MW considering 2% of the total anticipated peak demand met in MW in NR Import
		18-24	18450 17500**	1000	17450 16500**	11010 10060**	6440		
	1st September	00-06	2000		1800	193	1607		
NR-ER*	2021 to 30th	06-18	2000	200	1800	603	1197	1	
	September 2021	18-24	2000		1800	193	1607		
ER-NR*	1st September 2021 to 30th September 2021	00-24	6850	400	6450	4280	2170		Revised Reliability Margin (TRM) from 300 MW to 400 MW considering 2% of the total anticipated peak demand met in MW in NR Import
W3-ER	1st September 2021 to 30th September 2021	00-24					No limit is bein	g specified.	
ER-W3	1st September 2021 to 30th September 2021	00-24					No limit is bein	g specified.	
	1 . 0 . 1	00-05	9350		8700		4804		
WR-SR <sup>^</sup>	1st September 2021 to 30th	05-22	9350	650	8700	3896	4804		
WK-SK	September 2021	22-24	9350	050	8700	3070	4804		
SR-WR*	1st September 2021 to 30th September 2021	00-24	4600	400	4200	769	3431		
		00-06				2672	2728		
ER-SR <sup>^</sup>	1st September 2021 to 30th	06-18	5750	350	5400	2757	2643		
	September 2021	18-24				2672	2728		
SR-ER *	1st September 2021 to 30th September 2021	00-24					No limit is being	g Specified.	
		00-02	730		685	474	211		
	1st September	02-07	730		685	474	211		
ER-NER*	2021 to 30th	07-12	810	45	765	474	291		
	September 2021	12-18 18-22	740 590		695 545	474 474	221 71	-	
		22-24	730		685	474	211		
		00-02	3500		3455	83	3372		
	1 2	02-07	3500		3455	83	3372		
MED ED*	1st September 2021 to 30th	07-12	3490	15	3445	83	3362		
NER-ER*	September 2021	12-18	3440	45	3395	83	3312		
	2021	18-22	3390		3345	83	3262		
		22-24	3500		3455	83	3372		

### National Load Despatch Centre Total Transfer Capability for September 2021

Issue Date: 17th July, 2021 Issue Time: 1730 hrs Revision No. 3

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
W3 zone Injection	1st September 2021 to 30th September 2021	00-24	No limit is be	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)					

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\*\*Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

- 1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

# The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis.

In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropriate measures.

SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

#### **Simultaneous Import Capability Long Term** Margin Changes **Total Available** Time Access (LTA)/ Available for in TTC **Transfer Transfer** Reliability Corridor **Date** Period **Medium Term Short Term** w.r.t. **Comments** Capability **Capability** Margin (hrs) **Open Access Open Access** Last (TTC) (ATC) (MTOA) (STOA) Revision 23900 25300 15289 00-06 8611 24350\*\* 14339\*\* 22950\*\* 25300 23900 15678 06-09 8222 24350\*\* 22950\*\* 14728\*\* Revised Reliability Margin (TRM) from 1st September 25300 23900 15678 800 MW to 1400 MW considering 2% NR 2021 to 30th 09-17 1400 8222 of the total anticipated peak demand met September 2021 24350\*\* 22950\*\* 14728\*\* in MW in NR Import 25300 23900 15678 17-18 8222 24350\*\* 22950\*\* 14728\*\* 25300 23900 15289 18-24 8611 24350\*\* 22950\*\* 14339\*\* 00-02 474 211 730 685 02-07 730 685 474 211 1st September 07-12 810 765 474 291 2021 to 30th 45 **NER**\* 12-18 740 474 695 221 September 2021 474 18-22 590 545 71 22-24 730 685 474 211 $\mathbf{WR}^*$ 00-06 15100 14100 6570 7530 $744\overline{5}$ 15100 14100 6655 1st September 06-18 SR\*# 2021 to 30th 1000

14100

6570

7530

Margin in Simultaneous import of NR = A

September 2021

18-24

15100

WR-NR ATC =B

ER-NR ATC = C

Margin for WR-NR applicants = A \* B/(B+C)Margin for ER-NR Applicants = A \* C/(B+C)

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

<sup>\*\*</sup>Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

<sup>\*</sup> For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

2-NR/Import of NR TTC has been ca	lculated considering general	tion at Pariccha TPS as 3	350 MW. TTC figures are	subject to change with sig	gnificant change
eration at Pariccha TPS.		non at l'aricona 115 as c		subject to change with sig	

Simultaneous Export Capability										
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
	1st September	00-06	4500		3800	446	3354			
NR*	2021 to 30th September 2021	06-18	4500	700	3800	1942	1858			
		18-24	4500		3800	446	3354			
	1st September 2021 to 30th September 2021	00-02	3500	45	3455	83	3372			
		02-07	3500		3455	83	3372			
		07-12	3490		3445	83	3362			
NER*		12-18	3440		3395	83	3312			
		18-22	3390		3345	83	3262			
		22-24	3500		3455	83	3372			
WR*										
SR*^	1st September 2021 to 30th September 2021	00-24	3700	400	3300	1489	1811			

<sup>\*</sup> Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

Limiting	Constraints (Corridor wise)	
		<b>Applicable Revisions</b>
Corridor	Constraint	
WR-NR	N-1 contingency of 1500 MVA, 765/400 kV ICT at Agra will overload the other ICT	Rev- 0
	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 1 to 3
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 3
ER-NR	<ol> <li>N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt.</li> <li>Inter-regional flow pattern towards NR</li> </ol>	Rev- 0
211111	Inter-regional flow pattern towards NR	Rev- 1 to 3
WR-SR	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	
	N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit	Rev- 0 to 3
SK	Low Voltage at Gazuwaka (East) Bus.	
SR-WR	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0 to 3
	<ul> <li>a) N-1 contingency of 400 kV Bongaigaon - Azara line</li> <li>b) High Loading of 220 kV Salakati - BTPS D/C</li> </ul>	Rev- 0 to 3
NER-ER	<ul> <li>a) N-1 contingency of 220 kV Salakati - Alipurduar I or II</li> <li>b) High Loading of 220 kV Salakati - Alipurduar II or I</li> </ul>	Rev- 0 to 3
W3 zone Injection		Rev- 0 to 3

## **Limiting Constraints (Simultaneous)**

g	0 0 1 2 0 1 1 1 1 1 1	(Dimutaneous)	<b>Applicable Revisions</b>	
		<ol> <li>N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt.</li> <li>Inter-regional flow pattern towards NR</li> </ol>	Rev- 0	
ND	Import	Inter-regional flow pattern towards NR	Rev- 1 to 3	
NR		N-1 contingency of 1500 MVA, 765/400 kV ICT at Agra will overload the other ICT	Rev- 0	
		N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 1 to 3	
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	Rev- 0 to 3	
	Export	(n-1) contingency of 400 kV Saranath-Pusauli	100 0 10 3	
NED	Import	<ul><li>a) N-1 contingency of 400 kV Bongaigaon - Azara line</li><li>b) High Loading of 220 kV Salakati - BTPS D/C</li></ul>	Rev- 0 to 3	
NER	Export	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II b) High Loading of 220 kV Salakati - Alipurduar II or I	Rev- 0 to 3	
		N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT		
	Import	N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit	Rev- 0 to 3	
SR		Low Voltage at Gazuwaka (East) Bus		
	Export	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt	Rev- 0 to 3	
	Export	N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Nev- 0 to 3	

### National Load Despatch Centre Total Transfer Capability for September 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected		
			a) Reversal in HVDC APD-Agra flow			
1	4th June 2021	Whole month	b) Commissioning of 765kV Ajmer-Phagi D/C and 765kV G.Noida-Fatehabad S/C	WR-NR, ER-NR & NR Import		
			a) Revised STOA margin due to decrease in LTA allocations by 5 MW (90 MW to 85 MW) from AWEK1L to UPPCL			
		Whole month	b) Revised STOA margin due to increase in LTA allocations by 21 MW (19 MW to 40 MW) from AWEK1L to Chandigarh	WR-NR/NR Import		
2	28th June 2021		Revised STOA margin due to increase in LTA allocations by 10 month MW (65 MW to 75 MW) from AWEKTL-WR to KSEB			
			Revised STOA margin due to increase in LTA allocation by 4 MW (62 MW to 68 MW) from BETAM to UP (NR)	SR-WR		
			Revised STOA margin due to increase in LTA allocation from BETAM to UP (NR) & Odisha each by 4 MW (62 MW to 8MW)	SR Export		
3	17th July 2021	Whole month	Revised Reliability Margin (TRM) considering 2% of the total anticipated peak demand met in MW in NR Import	WR-NR, ER-NR & NR Import		

ASSUN	MPTIONS IN BASECASE					
				Month : September 20	<u> </u>	
S.No.	Name of State/Area		Load	Generation		
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)	
I	NORTHERN REGION					
1	Punjab	10744	10867	3971	3971	
2	Haryana	9492	9088	2701	2701	
3	Rajasthan	10485	9635	8259	8259	
4	Delhi	5321	5152	796	795	
5	Uttar Pradesh	20631	20099	10623	10689	
6	Uttarakhand	2124	1886	928	939	
7	Himachal Pradesh	1354	1114	783	769	
8	Jammu & Kashmir	2363	1962	884	883	
9	Chandigarh	313	249	0	0	
10	ISGS/IPPs	48	48	21958	20013	
	Total NR	62875	60100	50903	49019	
II	EASTERN REGION					
1	Bihar	6537	5617	356	349	
2	Jharkhand	1958	1503	511	501	
3	Damodar Valley Corporation	2985	2723	5856	4190	
4	Orissa	4513	4310	3998	3798	
5	West Bengal	9704	8401	7033	6210	
6	Sikkim	119	116	0	0	
7	Bhutan	181	181	2325	2325	
8	ISGS/IPPs	810	810	15771	11533	
	Total ER	26808	23662	35850	28906	
III	WESTERN REGION					
1	Maharashtra	17405	16509	11624	10789	
2	Gujarat	13918	11320	8601	7246	
3	Madhya Pradesh	9254	8534	3596	3845	
4	Chattisgarh	4309	3965	2531	2835	
5	Daman and Diu	276	236	0	0	
6	Dadra and Nagar Haveli	744	870	0	0	
7	Goa-WR	534	420	0	0	
8	ISGS/IPPs	1784	3263	36712	32338	
-	Total WR	48224	45117	63064	57053	

	ı				
IV	SOUTHERN REGION				
1	Andhra Pradesh	8024	7220	6268	5204
2	Telangana	9100	8117	5196	5078
3	Karnataka	8396	6654	6023	4850
4	Tamil Nadu	15210	13068	7256	6376
5	Kerala	3778	2349	1614	961
6	Pondy	264	264	0	0
7	Goa-SR	82	82	0	0
8	ISGS/IPPs	37	37	14805	14794
	Total SR	44891	37791	41162	37263
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	140	95	118	118
2	Assam	1849	1588	615	574
3	Manipur	207	86	105	103
4	Meghalaya	315	255	302	229
5	Mizoram	150	55	60	60
6	Nagaland	173	155	96	93
7	Tripura	435	260	300	300
8	ISGS/IPPs	0	0	2371	2370
	Total NER	3269	2494	3967	3847
	Total All India	186067	169164	194946	176088