

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Jan 2022

Issue Date: 26th Sept 2021

Issue Time: 1500 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Jan 2022 to 31st Jan 2022	00-24	2590	50	2540	3188	-645		
Limiting Constraints		N-1 contingency of (a) 2X 315 MVA, 400/220kV NSPCL ICTs, (b) 2X 315 MVA, 400/220kV Bhatapara ICTs, (c) 2X 315 MVA, 400/220kV Raigarh-PG ICTs						

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Jan 2022

Revision No	Date of Revision	Period of Revision	Reason for Revision