

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Oct 2021

Issue Date: 20th July 2021

Issue Time: 1500 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Oct 2021 to 31st Oct 2021	00-24	2430	50	2380	2071	309	380	Import capability of Chhattisgarh is re-assessed after 400kV Korba-Raipur-3,4 and 400kV Raipur - Bhadrawati - 2,3 feeders swapped at 400kV Raipur bus sections and 220kV feeder re-arrangements in Chhattisgarh intra-state network.
Limiting Constraints		N-1 contingency of 220 kV Raigarh-PG-Raigarh-CG-1						

National Load Despatch Centre
Import of Chhattisgarh Transfer Capability for Oct 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	20th July 2021	Whole Month	Import capability of Chhattisgarh is re-assessed after 400kV Korba-Raipur-3,4 and 400kV Raipur - Bhadrawati - 2,3 feeders swapped at 400kV Raipur bus sections and 220kV feeder re-arrangements in Chhattisgarh intra-state network.