

**National Load Despatch Centre**  
**Import of Chhattisgarh Transfer Capability for Sept 2021**

Issue Date: 26th May 2021

Issue Time: 1200 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st Sept 2021 to 30th Sept 2021	00-24	2050	50	2000	2071	-71		
<b>Limiting Constraints</b>		N-1 contingency of 2X 315 MVA, 400/220kV NSPCL ICTs						

**National Load Despatch Centre**  
**Import of Chhattisgarh Transfer Capability for Sept 2021**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>