## National Load Despatch Centre Import of Chhattisgarh Transfer Capability for September 2021

| Issue Date: 20th                                | h July 2021                 | Issue Time: 1500 hrs                              |                       |  |  |  | Revision No. 1                            |   |  |
|---|-----------------------------|---|-----------------------|--|--|--|---|---|--|
| Date  | Time Period in<br>IST (hrs) | Total<br>Transfer<br>Capability<br>(TTC)          | Reliability<br>Margin | Available<br>Transfer<br>Capability<br>(ATC) | Long Term<br>Access (LTA)/<br>Medium Term<br>Open Access<br>(MTOA) # | Margin<br>Available for<br>Short Term<br>Open Access<br>(STOA) | Changes in TTC<br>w.r.t. Last<br>Revision | Comments  |  |
| 1st September<br>2021 to 30th<br>September 2021 | 00-24                       | 2430  | 50                    | 2380   | 2071   | 309  | 380                                       | Import capability of Chhattisgarh is<br>re-assessed after 400kV Korba-<br>Raipur-3,4 and 400kV Raipur -<br>Bhadrawati - 2,3 feeders swapped<br>at 400kV Raipur bus sections and<br>220kV feeder re-arrangements in<br>Chhattisgarh intra-state network. |  |
| Limiting Constraints                            |                             | N-1 contingency of 220 kV Raigarh-PG-Raigarh-CG-1 |                       |  |  |  |   |   |  |

## National Load Despatch Centre Import of Chhattisgarh Transfer Capability for September 2021

| Revision | Date of           | Period of   | Reason for Revision   |
|----------|-------------------|-------------|---|
| No       | Revision          | Revision    |   |
| 1        | 20th July<br>2021 | Whole Month | Import capability of Chhattisgarh is re-assessed after 400kV<br>Korba-Raipur-3,4 and 400kV Raipur - Bhadrawati - 2,3<br>feeders swapped at 400kV Raipur bus sections and 220kV<br>feeder re-arrangements in Chhattisgarh intra-state network. |