National Load Despatch Centre, New Delhi

Cross Border Transfer Capability for Dec 2025

Issue Date: 27-01-2025 Issue Time: 1500 hrs Revision No. 4

Issue Date: 27-01-2	023	1	18	ssue Time: 1.	500 nrs	1	Revision No	. 4	T	
Cross-Border Corridor	Date	Time Period in IST (hrs)	ттс	Reliability Margin	Available Transfer Capability (ATC)	General Network Access (GNA)	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments
India (ER ISTS) to Bangladesh *	1st Dec 2025 to 31st Dec 2025	00:00-17:00	1000	0	1000	982	18		Limited to HVDC Bherama-Behrampore rated capacity	
		17:00-21:00	1000		1000	982	18			
		21:00-24:00	1000		1000	982	18			
Bangladesh to India (ER ISTS) *	1st Dec 2025 to 31st Dec 2025	00:00-17:00	1000	0	1000	0	1000		Limited to HVDC Bherama-Behrampore rated capacity	
		17:00-21:00	1000		1000	0	1000			
		21:00-24:00	1000		1000	0	1000			
	1st Dec 2025 to 31st Dec 2025	00:00-17:00	200	-	200	0	200		Limited to terminal bay rating at 132 kV Surjamaninagar (TSCL)	
India (Tripura) to Bangladesh #		17:00-21:00	200		200	0	200			
		21:00-24:00	200		200	0	200			
Bangladesh to India (Tripura) #	1st Dec 2025 to 31st Dec 2025	00:00-17:00	200	-	200	0	200		Limited to terminal bay rating at 132 kV Surjamaninagar (TSCL)	
		17:00-21:00	200		200	0	200			
		21:00-24:00	200		200	0	200			
India (ER ISTS & NER ISTS) to Bhutan *	1st Dec 2025 to 31st Dec 2025	00:00-17:00	1100	0	1100	0	1100		1. N-1 of Chukha-Birpara will overload the other circuit 2. Outage of any circuit of 220 kV Birpara - Alipurduar D/C will overload the other circuit, 3. The outage of any one circuit of 220 kV Birpara-Chukha D/C will overload 220 kV Birpara – Malbase 4. Low Voltage in NER system	
		17:00-21:00	1100		1100	0	1100			
		21:00-24:00	1100		1100	0	1100			
Bhutan to India (ER ISTS) *	1st Dec 2025 to 31st Dec 2025	00:00-17:00	2380	50	2330	2185	145		N-1 of Chukha-Birpara will overload the other circuit	
		17:00-21:00	2380		2330	2185	145			
		21:00-24:00	2380		2330	2185	145			
Bhutan to India (NER ISTS) *	1st Dec 2025 to 31st Dec 2025	00:00-17:00	158	-	158	0	158		Limited to loading upto the thermal limit of 132 kV Salaktai-Gelephu & 132 kV Rangia-Motonga	
		17:00-21:00	158		158	0	158			
		21:00-24:00	158		158	0	158			
		00:00-17:00	300		300	0	300		(i) Overloading of 220/132kv, 3x160MVA ICTs at Kishanganj. (ii) Limited to thermal limit of 132 kV Raxual Parwanipur D/C.	
India (Bihar) to Nepal ##	1st Dec 2025 to 31st Dec 2025	17:00-21:00	300	0	300	0	300		(iii) Limited to thermal limit of 132 KV Bettiah - Ramnagar, 132 KV Bettia - Thakraha 132 KV Bettiah – Narkatiyaganj lines.	

National Load Despatch Centre, New Delhi Cross Border Transfer Capability for Dec 2025

Issue Date: 27-01-2025 Issue Time: 1500 hrs Revision No. 4

Cross-Border Corridor	Date	Time Period in IST (hrs)	ттс	Reliability Margin	Available Transfer Capability (ATC)	General Network Access (GNA)	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments
		21:00-24:00	300		300	0	300			
India (NR ISTS) to Nepal *		00:00-17:00	80	-	80	0	80		Limited to ampacity of 132 kV Tanakpur- Mahendranagar S/C line	
	1st Dec 2025 to 31st Dec 2025	17:00-21:00	80		80	0	80			
		21:00-24:00	80		80	0	80			
India (UP) to Nepal ###	1st Dec 2025 to 31st Dec 2025	00:00-24:00	50	0	50	0	50		Overloading of 132 kV Anand Nagar – New Nautanwa under outage of 132 kV New Nautanwa – Bansi S/C.	
	1st Dec 2025 to 31st Dec 2025	00:00-17:00	80	0	80	0	80		Limited to ampacity of 132 kV Tanakpur- Mahendranagar S/C line	
Nepal to India (NR ISTS) *		17:00-21:00	80		80	0	80			
		21:00-24:00	80		80	0	80			
India (ER ISTS) to Nepal *	1st Dec 2025 to 31st Dec 2025	00:00-17:00	1000	0	1000	0	1000		N-1 Contingency of 400kV Dhalkebar- Muzaffarpur Line D/C will overload the other circuit.	
		17:00-21:00	1000		1000	0	1000			
		21:00-24:00	1000		1000	0	1000			
	1st Dec 2025 to 31st Dec 2025	00:00-17:00	1000	0	1000	0	1000		N-1 Contingency of 400kV Dhalkebar- Muzaffarpur Line D/C will overload the other circuit.	
Nepal to India (ER ISTS) *		17:00-21:00	1000		1000	0	1000			
		21:00-24:00	1000		1000	0	1000			
India (Manipur) to Myanmar #	1st Dec 2025 to 31st Dec 2025	00:00-17:00	3.4	-	3.4	0	3.4		Limited to loading upto the thermal limit of 11 kV Moreh -Tamu	
		17:00-21:00	3.4		3.4	0	3.4			
		21:00-24:00	3.4		3.4	0	3.4			
Myanmar to India (Manipur) #	1st Dec 2025 to 31st Dec 2025	00:00-17:00	3.4	- - -	3.4	0	3.4		Limited to loading upto the thermal limit of 11 kV Moreh -Tamu	
		17:00-21:00	3.4		3.4	0	3.4			
		21:00-24:00	3.4		3.4	0	3.4			

Note 1:	In case of operation of SPS, Transfer Capability will be revised accordingly.					
Note 2:	Schedule between India and Bangladesh will be prepared using the above table till the next revision					
Note 3:	Transfer Capability between India and Bangladesh in the above table has been evaluated ignoring the constraints from Bangladesh side.					
Note 4:	Deemed GNA of Bangladesh from India is considered as 300 MW from DVC, 450 MW from Sembcorp Energy India Limited and 232 MW from ISGS allocation (excluding auxiliaries+losses).					
Note 5:	* ISTS to cross-border TTC/ATC is for security & market purpose.					
Note 6:	# Intra-state to cross-border TTC/ATC is for security purpose only					
Note 7:	## TTC is the sum of individual maximum permissible load as Nepal is fed radially & declared by SLDC Bihar.					
Note 8:	### The transfer capability from UP to Nepal through 132 kV Nautanwa – Mainhiya D/C line					

National Load Despatch Centre, New Delhi Cross Border Transfer Capability for Dec 2025

Issue Date: 27-01-2025 Issue Time: 1500 hrs Revision No. 4 Available Changes in General Margin Cross-Border Time Period in Reliability Transfer TTC w.r.t. TTC Date Available for Limiting constraint Comments Network Corridor IST (hrs) Margin Capability Last Access (GNA) T-GNA (ATC) Revision The above limits are considering the network limitation on Indian side. In case cross-border NLDC also declare the TTC/ATC considering the network limitation on their respective side, the Note 9: lower of this values vs values in above table would be reckoned for the purpose of scheduling. Note 10: In case any other constraint would be intimated by respective cross-border NLDC, these figures would be revised accordingly. NLDC India would approve the transactions in line with the GOI guidelines of Dec 2018, CERC Cross Border regulations and the CBTE procedure issued by DA. http://powermin.nic.in/sites/default/files/uploads/Guidelines for ImportExport Cross%20Border of Electricity 2018.pdf Note 11: http://www.cercind.gov.in/2019/regulation/CBTE-Regulations2019.pdf https://cea.nic.in/wp-content/uploads/2021/02/Final DA Procedure 26022021.pdf

Cross Border Transfer Capability for Oct 2025

Revision No	Date of Revision	Period of Revision	Reason for Revision		
1	30th April 2024	1st Nov 2024 to 30th Nov 2024	Change in LGB and assessment of transfer capability from UP to Nepal through 132 kV Nautanwa – Mainhiya D/C line		
2	1st Oct 2025 to 31st Oct 2025	6th Nov 2024 to 30th Nov 2024	Change in LGB and assessment of transfer capability from India (ER-ISTS + NER-ISTS) to Bhutan		
3	7th November 2024	8th November 2024	Due to the shutdown of 220KV MAIN BUS - 1 & 2 AT BIRPARA, 220KV-BIRPARA-MALBASE-1 & 220KV-CHUKHA- BIRPARA-1 & 2		
4	27th Jan 2024	1st Feb 2024	Commissioning of 4th 400/220 kV 315 MVA Dhalkebar S/s ICT		