## National Load Despatch Centre, New Delhi

Cross Border Transfer Capability for May 2025

Issue Date: 07 Nov	ember 2024	[	I	ssue Time: 1	500 hrs		Revision No	. 3	[]
Cross-Border Corridor	Date	Time Period in IST (hrs)	TTC	Reliability Margin	Available Transfer Capability (ATC)	General Network Access (GNA)	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Limiting constraint Comments
		00:00-17:00	1000		1000	982	18		
India (ER ISTS) to Bangladesh *	1st May 2025 to 30th May 2025	17:00-21:00	1000	0	1000	982	18		Limited to HVDC Bherama-Behrampore rated capacity
		21:00-24:00	1000		1000	982	18		
		00:00-17:00	1000	0	1000	0	1000		
Bangladesh to India (ER ISTS) *	1st May 2025 to 30th May 2025	17:00-21:00	1000		1000	0	1000		Limited to HVDC Bherama-Behrampore rated capacity
		21:00-24:00	1000		1000	0	1000		
	1st May 2025 to 30th May 2025	00:00-17:00	200		200	0	200		
India (Tripura) to Bangladesh #		17:00-21:00	200	-	200	0	200		Limited to terminal bay rating at 132 kV Surjamaninagar (TSCL)
		21:00-24:00	200		200	0	200		
Bangladesh to India (Tripura) #	1st May 2025 to 30th May 2025	00:00-17:00	200	-	200	0	200		
		17:00-21:00	200		200	0	200		Limited to terminal bay rating at 132 kV Surjamaninagar (TSCL)
		21:00-24:00	200		200	0	200		
India (ER ISTS & NER ISTS) to Bhutan *	1st May 2025 to 30th May 2025	00:00-17:00	1100	0	1100	0	1100		1. N-1 of Chukha-Birpara will overload the other circuit
		17:00-21:00	1100		1100	0	1100		<ol> <li>Outage of any circuit of 220 kV</li> <li>Birpara - Alipurduar D/C will overload the other circuit,</li> <li>The outage of any one circuit of 220</li> </ol>
		21:00-24:00	1100		1100	0	1100		kV Birpara-Chukha D/C will overload 220 kV Birpara – Malbase 4. Low Voltage in NER system
	1st May 2025 to 30th May 2025	00:00-17:00	2380	0 50	2330	2185	145		
Bhutan to India (ER ISTS) *		17:00-21:00	2380		2330	2185	145		N-1 of Chukha-Birpara will overload the other circuit
		21:00-24:00	2380		2330	2185	145		
Bhutan to India (NER ISTS ) *	1st May 2025 to 30th May 2025	00:00-17:00	158	-	158	0	158		Limited to loading upts the thermal V
		17:00-21:00	158		158	0	158		Limited to loading upto the thermal limit of 132 kV Salaktai-Gelephu & 132 kV Rangia-Motonga
		21:00-24:00	158		158	0	158		
		00:00-17:00	300		300	0	300		<ul> <li>(i) Overloading of 220/132kv,</li> <li>3x160MVA ICTs at Kishanganj.</li> <li>(ii) Limited to thermal limit of 132 kV</li> <li>Raxual Parwanipur D/C.</li> </ul>
India (Bihar ) to Nepal ##	1st May 2025 to 30th May 2025	17:00-21:00	300	0	300	0	300		<ul> <li>(iii) Limited to thermal limit of 132 KV</li> <li>Bettiah - Ramnagar, 132 KV Bettia -</li> <li>Thakraha 132 KV Bettiah –</li> <li>Narkatiyaganj lines.</li> </ul>

## National Load Despatch Centre, New Delhi

Cross Border Transfer Capability for May 2025

Issue Date: 07 Nov	ember 2024	I	Issue Time: 1500 hrs				Revision No. 3			
Cross-Border Corridor	Date	Time Period in IST (hrs)	ттс	Reliability Margin	Available Transfer Capability (ATC)	General Network Access (GNA)	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments
		21:00-24:00	300		300	0	300			
		00:00-17:00	80	_	80	0	80			
India (NR ISTS) to Nepal *	1st May 2025 to 30th May 2025	17:00-21:00	80		80	0	80		Limited to ampacity of 132 kV Tanakpur- Mahendranagar S/C line	
		21:00-24:00	80		80	0	80			
India (UP ) to Nepal ###	1st May 2025 to 30th May 2025	00:00-24:00	50	0	50	0	50		Overloading of 132 kV Anand Nagar – New Nautanwa under outage of 132 kV New Nautanwa – Bansi S/C.	
Nepal to India (NR ISTS) *	1st May 2025 to 30th May 2025	00:00-17:00	80	0	80	0	80			
		17:00-21:00	80		80	0	80		Limited to ampacity of 132 kV Tanakpur- Mahendranagar S/C line	
		21:00-24:00	80		80	0	80			
	1st May 2025 to 30th May 2025	00:00-17:00	800	0	800	0	800			
India (ER ISTS ) to Nepal *		17:00-21:00	800		800	0	800		Limited on account of transformation capacity at 400/220 kV Dhalkebar S/s	
		21:00-24:00	800		800	0	800			
	1st May 2025 to 30th May 2025	00:00-17:00	800	00 0	800	0	800			
Nepal to India (ER ISTS ) *		17:00-21:00	800		800	0	800		Limited on account of transformation capacity at 400/220 kV Dhalkebar S/s	
		21:00-24:00	800		800	0	800			
India (Manipur ) to Myanmar #	1st May 2025 to 30th May 2025	00:00-17:00	3.4	-	3.4	0	3.4			
		17:00-21:00	3.4		3.4	0	3.4		Limited to loading upto the thermal limit of 11 kV Moreh -Tamu	
		21:00-24:00	3.4		3.4	0	3.4			
Myanmar to India (Manipur)#	1st May 2025 to 30th May 2025	00:00-17:00	3.4	-	3.4	0	3.4			
		17:00-21:00	3.4		3.4	0	3.4		Limited to loading upto the thermal limit of 11 kV Moreh -Tamu	
		21:00-24:00	3.4		3.4	0	3.4			

Note 1:	In case of operation of SPS, Transfer Capability will be revised accordingly.							
Note 2:	Schedule between India and Bangladesh will be prepared using the above table till the next revision							
Note 3:	Transfer Capability between India and Bangladesh in the above table has been evaluated ignoring the constraints from Bangladesh side.							
Note 4:	Deemed GNA of Bangladesh from India is considered as 300 MW from DVC, 450 MW from Sembcorp Energy India Limited and 232 MW from ISGS allocation (excluding auxiliaries+losses).							
Note 5:	* ISTS to cross-border TTC/ATC is for security & market purpose.							
Note 6:	# Intra-state to cross-border TTC/ATC is for security purpose only							
Note 7:	## TTC is the sum of individual maximum permissible load as Nepal is fed radially & declared by SLDC Bihar.							
Note 8:	### The transfer capability from UP to Nepal through 132 kV Nautanwa – Mainhiya D/C line							

## National Load Despatch Centre, New Delhi

Cross Border Transfer Capability for May 2025

Issue Date: 07 November 2024			Issue Time: 1500 hrs			Revision No. 3					
Cross-Border Corridor	Date	Time Period in IST (hrs)	TTC	Reliability Margin	Available Transfer Capability (ATC)	General Network Access (GNA)	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments	
Note 9:	The above limits are considering the network limitation on Indian side. In case cross-border NLDC also declare the TTC/ATC considering the netowrk limitation on their respective side, the lower of this values vs values in above table would be reckoned for the purpose of scheduling.										
Note 10 :	In case any other constraint would be intimated by respective cross-border NLDC, these figures would be revised accordingly.										
	NLDC India would approve the transactions in line with the GOI guidelines of Dec 2018, CERC Cross Border regulations and the CBTE procedure issued by DA.										
Note 11 :	http://powermin.nic.in/sites/default/files/uploads/Guidelines for ImportExport Cross%20Border of Electricity 2018.pdf										
	http://www.cercind.gov.in/2019/regulation/CBTE-Regulations2019.pdf_										
	https://cea.nic.in/wp-content/uploads/2021/02/Final_DA_Procedure_26022021.pdf										