National Load Despatch Centre, New Delhi

Cross Border Transfer Capability for Sept 2025

Issue Date: 07 November 2024 Issue Time: 1500 hrs Revision No. 3 Available Changes in Margin General Cross-Border Time Period in Reliability Transfer TTC w.r.t. Date TTC Network Available for Limiting constraint Comments Corridor IST (hrs) Margin Capability Last Access (GNA) T-GNA (ATC) Revision 00:00-17:00 1000 1000 982 18 India (ER ISTS) to 1st Sept 2025 to Limited to HVDC Bherama-Behrampore 0 17:00-21:00 1000 1000 982 18 Bangladesh 3 30th Sept 2025 rated capacity 21:00-24:00 1000 1000 982 18 00:00-17:00 1000 0 1000 1000 Bangladesh to India 1st Sept 2025 to Limited to HVDC Bherama-Behrampore 17:00-21:00 1000 0 1000 0 1000 (ER ISTS) * 30th Sept 2025 rated capacity 21:00-24:00 1000 1000 0 1000 00:00-17:00 200 200 0 200 India (Tripura) to 1st Sept 2025 to Limited to terminal bay rating at 132 kV 17:00-21:00 200 200 0 200 Bangladesh # 30th Sept 2025 Surjamaninagar (TSCL) 21:00-24:00 0 200 200 00:00-17:00 200 200 0 200 1st Sept 2025 to Bangladesh to India Limited to terminal bay rating at 132 kV 17:00-21:00 200 200 0 200 Surjamaninagar (TSCL) (Tripura) # 30th Sept 2025 21:00-24:00 0 200 200 200 1. N-1 of Chukha-Birpara will overload 00:00-17:00 1100 0 1100 1100 the other circuit 2. Outage of any circuit of 220 kV India (ER ISTS & Birpara - Alipurduar D/C will overload 1st Sept 2025 to NER ISTS) to Bhutan 17:00-21:00 1100 0 1100 0 1100 the other circuit. 30th Sept 2025 3. The outage of any one circuit of 220 kV Birpara-Chukha D/C will overload 220 kV Birpara – Malbase 21:00-24:00 1100 1100 0 1100 4. Low Voltage in NER system 00:00-17:00 2380 2330 2185 145 Bhutan to India (ER | 1st Sept 2025 to N-1 of Chukha-Birpara will overload the 17:00-21:00 2380 2330 2185 145 ISTS) * 30th Sept 2025 other circuit 21:00-24:00 2380 2330 2185 145 00:00-17:00 158 158 0 158 Limited to loading upto the thermal limit 1st Sept 2025 to Bhutan to India of 132 kV Salaktai-Gelephu & 132 kV 17:00-21:00 158 158 0 158 (NER ISTS)* 30th Sept 2025 Rangia-Motonga 21:00-24:00 158 158 0 158 (i) Overloading of 220/132kv,

00:00-17:00

17:00-21:00

1st Sept 2025 to

30th Sept 2025

India (Bihar) to

Nepal ##

300

300

0

300

300

0

0

300

300

3x160MVA ICTs at Kishanganj.

Raxual Parwanipur D/C.

Narkatiyaganj lines.

Thakraha 132 KV Bettiah -

(ii) Limited to thermal limit of 132 kV

(iii) Limited to thermal limit of 132 KV

Bettiah - Ramnagar, 132 KV Bettia -

National Load Despatch Centre, New Delhi Cross Border Transfer Capability for Sept 2025

Issue Date: 07 November 2024 Issue Time: 1500 hrs Revision No. 3

Cross-Border Corridor	Date	Time Period in IST (hrs)	ттс	Reliability Margin	Available Transfer Capability (ATC)	General Network Access (GNA)	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments
		21:00-24:00	300		300	0	300			
India (NR ISTS) to Nepal *	1st Sept 2025 to 30th Sept 2025	00:00-17:00	80	-	80	0	80		Limited to ampacity of 132 kV Tanakpur- Mahendranagar S/C line	
		17:00-21:00	80		80	0	80			
		21:00-24:00	80		80	0	80			
India (UP) to Nepal ###	1st Sept 2025 to 30th Sept 2025	00:00-24:00	50	0	50	0	50		Overloading of 132 kV Anand Nagar – New Nautanwa under outage of 132 kV New Nautanwa – Bansi S/C.	
	1st Sept 2025 to 30th Sept 2025	00:00-17:00	80	0	80	0	80		Limited to ampacity of 132 kV Tanakpur- Mahendranagar S/C line	
Nepal to India (NR ISTS) *		17:00-21:00	80		80	0	80			
		21:00-24:00	80		80	0	80			
	1st Sept 2025 to 30th Sept 2025	00:00-17:00	800	0	800	0	800		Limited on account of transformation capacity at 400/220 kV Dhalkebar S/s	
India (ER ISTS) to Nepal *		17:00-21:00	800		800	0	800			
		21:00-24:00	800		800	0	800			
	1st Sept 2025 to 30th Sept 2025	00:00-17:00	800	0	800	0	800		Limited on account of transformation capacity at 400/220 kV Dhalkebar S/s	
Nepal to India (ER ISTS) *		17:00-21:00	800		800	0	800			
		21:00-24:00	800		800	0	800			
India (Manipur) to Myanmar #	1st Sept 2025 to 30th Sept 2025	00:00-17:00	3.4	-	3.4	0	3.4		Limited to loading upto the thermal limit of 11 kV Moreh -Tamu	
		17:00-21:00	3.4		3.4	0	3.4			
		21:00-24:00	3.4		3.4	0	3.4			
Myanmar to India (Manipur) #	1st Sept 2025 to 30th Sept 2025	00:00-17:00	3.4	- - -	3.4	0	3.4		Limited to loading upto the thermal limit of 11 kV Moreh -Tamu	
		17:00-21:00	3.4		3.4	0	3.4			
		21:00-24:00	3.4		3.4	0	3.4			

Note 1:	In case of operation of SPS, Transfer Capability will be revised accordingly.					
Note 2:	Schedule between India and Bangladesh will be prepared using the above table till the next revision					
Note 3:	Transfer Capability between India and Bangladesh in the above table has been evaluated ignoring the constraints from Bangladesh side.					
Note 4:	Deemed GNA of Bangladesh from India is considered as 300 MW from DVC, 450 MW from Sembcorp Energy India Limited and 232 MW from ISGS allocation (excluding auxiliaries+losses).					
Note 5:	* ISTS to cross-border TTC/ATC is for security & market purpose.					
Note 6:	# Intra-state to cross-border TTC/ATC is for security purpose only					
Note 7:	## TTC is the sum of individual maximum permissible load as Nepal is fed radially & declared by SLDC Bihar.					
Note 8:	### The transfer capability from UP to Nepal through 132 kV Nautanwa – Mainhiya D/C line					

National Load Despatch Centre, New Delhi

Cross Border Transfer Capability for Sept 2025

Issue Date: 07 November 2024			Issue Time: 1500 hrs				Revision No. 3				
Cross-Border Corridor	Date	Time Period in IST (hrs)	ттс	Reliability Margin	Available Transfer Capability (ATC)	General Network Access (GNA)	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments	
Note 9:	The above limits are considering the network limitation on Indian side. In case cross-border NLDC also declare the TTC/ATC considering the netowrk limitation on their respective side, the lower of this values vs values in above table would be reckoned for the purpose of scheduling.										
Note 10:	In case any other constraint would be intimated by respective cross-border NLDC, these figures would be revised accordingly.										
	NLDC India would approve the transactions in line with the GOI guidelines of Dec 2018, CERC Cross Border regulations and the CBTE procedure issued by DA.										
Note 11 :	http://powermin.nic.in/sites/default/files/uploads/Guidelines for ImportExport Cross%20Border of Electricity 2018.pdf										
	http://www.cercind.gov.in/2019/regulation/CBTE-Regulations2019.pdf										
	https://cea.nic.in/wp-content/uploads/2021/02/Final DA Procedure 26022021.pdf										

Cross Border Transfer Capability for Sept 2025

Revision No	Date of Revision	Period of Revision	Reason for Revision		
1	30th April 2024	1st Nov 2024 to 30th Nov 2024	Change in LGB and assessment of transfer capability from UP to Nepal through 132 kV Nautanwa – Mainhiya D/C line		
2	1st Sept 2025 to 30th Sept 2025	6th Nov 2024 to 30th Nov 2024	Change in LGB and assessment of transfer capability from India (ER-ISTS + NER-ISTS) to Bhutan		
3	7th November 2024	8th November 2024	Due to the shutdown of 220KV MAIN BUS - 1 & 2 AT BIRPARA, 220KV-BIRPARA-MALBASE-1 & 220KV-CHUKHA- BIRPARA-1 & 2		