



POWER SYSTEM OPERATION CORPORATION  
NATIONAL LOAD DESPATCH CENTRE

B-9, QUTUB INSTITUTIONAL AREA,  
KATWARIA SARAI, NEW DELHI- 110016

Message No:- 009/106

Date: 12/9/16 Time: 12:14 hrs

From:- Shift Charge Manager, NLDC

To:- SCM

NRLDC WRLDC SRLDC ERLDC NERLDC

Sub:- Revision of TTC/ATC on account of Tripping/Revival of power system elements.

FOR-12/9/16

Sr. No.	Corridor	Current (MW)		Revised (MW)		Time Blocks	Reason for Revision
		TTC	ATC	TTC	ATC		
1	WR → NR	6800	6300	5800	5300	53-96	Tripping of 400 kV Mahendragadh - Dhanodga - D/C
2	NR Import	10800	10000	9200	8400	53-72	
		10000	9200	8500	7700	73-92	
		10800	10000	9200	8400	93-96	

SCM, NLDC