

National Load Despatch Centre
Import of DNHDDPDCL Transfer Capability for December 2023

Issue Date: 28th August 2023

Issue Time: 1700 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Control area | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|-------------------------------|--------------------------|--------------|---|--------------------|-------------------------------------|--|--|-------------------------------------|--------------------------------|
| 1st Dec 2023 to 31st Dec 2023 | 00-24 | DNHDDPDCL | 1310 | 25 | 1285 | 1492 | 0 | | Allocated LTA is more than ATC |
| | 00-24 | DNH | 840 | 15 | 825 | 1163 | 0 | | Allocated LTA is more than ATC |
| | 00-24 | DD | 470 | 10 | 460 | 329 | 131 | | |
| Limiting Constraints | | | DNH: N-1 contingency of 220 kV Kala-Khadoli D/C | | | | | | |
| | | | DD: N-1 contingency of 220 kV Magarwada-Magarwada(DD)-D/c | | | | | | |

****This total TTC/ATC is for mentioning in SCADA and WRLDC website for DNHDDPDCL. In real time, ATC violations would be monitored separately for DD&DNH.**

Import of DNHDDPDCL Transfer Capability for December 2023

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|----------------------------|
| | | | |