

National Load Despatch Centre
Import of DNHDDPDCL Transfer Capability for Feb'26

Issue Date: 28th Feb 2025

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Control area	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st to 28th Feb'26	00-24	DNHDDPDCL	1375	30	1345	1206	139		
	00-24	DNH	475	10	465	384	81		
	00-24	DD	900	20	880	822	58		
Limiting Constraints			DNH: N-1 contingency of 220 kV Kala-Khadoli D/C						
			DD: N-1 contingency of 220 kV Magarwada (PG)-Ringanwada (DD) D/C						

****This total TTC/ATC is for mentioning in SCADA and WRLDC website for DNHDDPDCL. In real time, ATC violations would be monitored separately for DD&DNH.**

Import of DNHDDPDCL Transfer Capability for Feb'26

Revision No	Date of Revision	Period of Revision	Reason for Revision