

National Load Despatch Centre
Import of DNHDDPDCL Transfer Capability for June 2023

Issue Date: 24th Feb 2023

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Control area	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2023 to 30th June 2023	00-24	DNHDDPDCL	1310	25	1285	1463.85	0		Limiting constraint will be same as defined for DNH and DD as separate control area.
	00-24	DNH	840	15	825	1141.77	0		Allocated LTA is more than ATC
	00-24	DD	470	10	460	323.23	0		
Limiting Constraints			DNH: N-1 contingency of 220 kV Kala-New Kharadpada- D/c						
			DD: N-1 contingency of 220 kV Magarwada-Magarwada(DD)-D/c						

****This total TTC/ATC is for mentioning in SCADA and WRLDC website for DNHDDPDCL. In real time, ATC violations would be monitored separately for DD&DNH.**

National Load Despatch Centre
Import of DNHDDPDCL Transfer Capability for June 2023

Revision No	Date of Revision	Period of Revision	Reason for Revision