

National Load Despatch Centre
Import of DNHDDPDCL Transfer Capability for June 2025

Issue Date: 28th June 2024

Issue Time: 1700 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Control area | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Approved GNA (MW) | Margin for T-GNA (MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---------------------------------|--------------------------|--------------|---|--------------------|-------------------------------------|-------------------|-----------------------|-------------------------------------|----------|
| 1st June 2025 to 30th June 2025 | 00-24 | DNHDDPDCL | 1310 | 25 | 1285 | 1126 | 159 | | |
| | 00-24 | DNH | 470 | 10 | 460 | 334 | 126 | | |
| | 00-24 | DD | 840 | 15 | 825 | 792 | 33 | | |
| Limiting Constraints | | | DNH: N-1 contingency of 220 kV Kala-Khadoli D/C | | | | | | |
| | | | DD: N-1 contingency of 220 kV Magarwada-Magarwada(DD)-D/c | | | | | | |

****This total TTC/ATC is for mentioning in SCADA and WRLDC website for DNHDDPDCL. In real time, ATC violations would be monitored separately for DD&DNH.**

Import of DNHDDPDCL Transfer Capability for June 2025

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|----------------------------|
| | | | |