

POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE
URGENT MARKET INFORMATION

Date of Issue:12-June-2012

Time of Issue: 15:00 Hrs

The TTC/ATC of ER-NR corridor is revised due to outage of 400KV Farakka-Kahalgaon 3 & 4 due to tower collapse on 11th June, 2012.

400kV Malda-Purnea D/C is already under shutdown from 07:00 hrs of 30/05/2012 to 16:00 hrs of 23/06/2012 on continuous basis due to modification & stringing work at Loc. No. 71 & 72.

Revised TTC/ATC

From 13-06-12 to 23-06-12

Link	Time period	TTC	RM	ATC
ER-NR	00:00-24:00	2700	300	2400
NR- ER	00:00-17:00	800	200	600
	17:00-23:00	900	200	700
	23:00-24:00	800	200	600

TTC/ATC shall be reviewed either restoration of 400kV Malda-Purnea D/C or 400kV Farakka-Kahalgaon 3 & 4.