

National Load Despatch Centre
Import of Bihar Transfer Capability for April 2022

Issue Date: 26th March 2022

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st April 2022 to 30th April 2022	00-24	6140	123	6017	7015	0		
		1.132kv Saharsa New-Sonebarsa 2. 123kv Saharsa New-Madhepura 3.220KV Muzaffarpur-Hazipurover loading on N-1 tripping of the other parallel ckt						

National Load Despatch Centre
Export of DVC Transfer Capability for April 2022

Issue Date: 26th March 2022

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st April 2022 to 30th April 2022	00-24	3553	53	3500	2660.69	839		In normal case(not extreme import or export),if 220 KV Waria-DStps-Parulia(DVC) d/c is in loop,flow of 220 KV DSTPS to WArea d/c may reach 190 MW each,which is a constraint
Limiting Constraints		Limited BY LGBR in extreme cases.For normal case,plz see comments.						

National Load Despatch Centre
Import of DVC Transfer Capability for April 2022

Issue Date: 26th March 2022

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st April 2022 to 30th April 2022	00-24	2030	67	1963	673	1290		In normal case(not extreme import or export).if 220 KV Waria-DStps-Parulia(DVC) is in loop,flow of 220 KV DSTPS to WArria may reach 190 MW each,which is a constraint
Limiting Constraints		Limited BY LGBR in extreme cases.For normal case,plz see comments.						

National Load Despatch Centre
Import of Jharkhand Transfer Capability for April 2022

Issue Date: 26th March 2022

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st April 2022 to 30th April 2022	00-24	1530	50	1480	1448	32		TOTAL GENERATION 404 MW, total load 1884 MW
Limiting Constraints		High Loading of 132 kV Adityapur-Rajkarswan						

National Load Despatch Centre
Export of odisha Transfer Capability for April 2022

Issue Date: 26th March 2022

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Counterflow on account of surrender of LTA(ISGS)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st April 2022 to 30th April 2022	00-24	1154	600	59	1695	1.82	1693		Generation: 4193MWLoad: 2973 MW
Limiting Constraints		Outage of one 210MW Generator of IBTPS Stage-1							

National Load Despatch Centre
Import of Odisha Transfer Capability for April 2022

Issue Date: 26th March 2022

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st April 2022 to 30th April 2022	00-24	3433	110	3323	2858	465		Generation: 2042 MW Load:4111 MW;plus Vedanta Generation: 200 MW Load:1401 MW
Limiting Constraints		N-1 contingency of one 220 kV Rourkella tarkera d/c,overloading the other ckt.(SPS is in service)						

National Load Despatch Centre
Import of Sikkim Transfer Capability for April 2022

Issue Date: 26th March 2022

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st April 2022 to 30th April 2022	peak 18:00 hrs	148	2.48	145.52	126.95	19		
1st April 2022 to 30th April 2022	off peak 03:00 hrs	160	1.8	158.2	126.95	31		
Limiting Constraints		Overloading of one of the two Gangtok 132/66 KV ICT due to N-1 tripping of the parallel ICT						

National Load Despatch Centre
Export of West Bengal Transfer Capability for April 2022

Issue Date: 26th March 2022

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st April 2022 to 30th April 2022	00-24	3950	450	3500	10	3490		TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit
Limiting Constraints		Limited By LGBR						

National Load Despatch Centre
Import of West Bengal Transfer Capability for April 2022

Issue Date: 26th March 2022

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st April 2022 to 30th April 2022	00-24	5661	450	5211	2521	2690		TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit
Limiting Constraints		Tripping of 400 kV Jeerat-Subhasgram causing Thermal loading violation of 220 kV Jeerat-Barasat D/C 208 MW						