

**National Load Despatch Centre**  
**Import of West Bengal Transfer Capability for June 2024**

Issue Date: 26th April 2024

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision	Remarks
1st June to 30th June 2025	00-12 hrs	7926	450	7476	3516.0	3960		TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 11374 MW Gen 6804 MW
1st June to 30th June 2025	12- 16 hrs	6908	450	6458	3516.0	2942		TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 11003 MW Gen 6225 MW
1st June to 30th June 2025	16-00 hrs	7926	450	7476	3516.0	3960		TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 11374 MW Gen 6804 MW
<b>Limiting Constraints</b>		1)Tripping of 400 kV Jeerat Subhasgram ckt creating constraints in Jeerat 400/220 KV 315 MVA ICTs in WBSEDCL peak 1) Tripping of 400 kV farakka Kahalgaon one ckt creating constraints in other ckt for CESC peak case Subhasgram ICTs N-1 constraints are not considered as SPS/LRS is enabled there						

**National Load Despatch Centre**  
**Import of West Bengal Transfer Capability for June 2024**

Issue Date: 26th April 2024

Issue Time: 1600 hrs

Revision N

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t. Last Revision
1st June to 30th June 2025	00-24	3950	450	3500	3516	-16	
		Limited By LGBR.No other constraints.					

No. 0

<b>Remarks</b>
TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit

\_\_\_\_\_

**National Load Despatch Centre**  
**Import of Sikkim Transfer Capability for June 2024**

Issue Date: 26th April 2024

Issue Time: 1600 hrs

Revision No. 0

[illegible]



**National Load Despatch Centre**

**Export of odisha Transfer Capability for June 2024**

Issue Date: 26th April 2024

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Counterflow on account of surrender of LTA(ISGS)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision	Remarks
1st June to 30th June 2025	00-24	1058		78	980	2157	-1177		Generation : 5048 MW Load: 3900 MW
Limiting Constraints			Outage of one 210MW Generator of IBTPS Stage-1						

\*Considering same figure of GNA as declared for import in CTU website

# National Load Despatch Centre

## Import of Jharkhand Transfer Capability for June 2024

Issue Date: 26th April 2024

Issue Time: 1600 hrs

Revision No. 0

[illegible]







**National Load Despatch Centre**  
**Import of Bihar Transfer Capability for June 2024**

Issue Date: 26th April 2024

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision
1st June to 30th June 2025	00 to 24 hrs	6175	121	6054	5043.0	1011	
		1.132kv Saharsa New-Sonebarsa					

\_\_\_\_\_

Remarks