

National Load Despatch Centre							
Import of West Bengal Transfer Capability for November 2024							

Issue Date: 26th April 2024			Issue Time: 1600 hrs				Revision No. 0	
Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Remarks
1st Nov to 30th Nov 2024	00-24	3950	450	3500	3516	-16		TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit
		Limited By LGBR.No other constraints.						

National Load Despatch Centre

Import of West Bengal Transfer Capability for November 2024

Issue Date: 26th April 2024

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Counterflow on account of surrender of LTA(ISGS)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision	Remarks
1st Nov to 30th Nov 2024	00-24	1058		78	980	2157	-1177		Generation : 5048 MW Load: 3900 MW
Limiting Constraints			Outage of one 210MW Generator of IBTPS Stage-1						

*Considering same figure of GNA as declared for import in CTU website

Revision No. 0

[illegible]

National Load Despatch Centre
Import of West Bengal Transfer Capability for November 2024

Issue Date: 26th April 2024

Issue Time: 1600 hrs

Revision No. 0

[illegible]

National Load Despatch Centre
Import of West Bengal Transfer Capability for November 2024

Issue Date: 26th April 2024

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision	Remarks
1st Nov to 30th Nov 2024	00 to 24 hrs	6175	121	6054	5043.0	1011		
		1.132kv Saharsa New-Sonebarsa						
