

**National Load Despatch Centre**  
**Import of West Bengal Transfer Capability for October 2024**

Issue Date: 26th April 2024

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision	Remarks
1st oct to 31th oct 2024	00-12 hrs	7926	450	7476	3516.0	3960		TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 11374 MW Gen 6804 MW
1st oct to 31th oct 2024	12- 16 hrs	6908	450	6458	3516.0	2942		TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 11003 MW Gen 6225 MW
1st oct to 31th oct 2024	16-00 hrs	7926	450	7476	3516.0	3960		TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit Demand 11374 MW Gen 6804 MW
<b>Limiting Constraints</b>		1)Tripping of 400 kV Jeerat Subhasgram ckt creating constraints in Jeerat 400/220 KV 315 MVA ICTs in WBSEDCL peak 1) Tripping of 400 kV farakka Kahalgaon one ckt creating constraints in other ckt for CESC peak case Subhasgram ICTs N-1 constraints are not considered as SPS/LRS is enabled there						

<b>National Load Despatch Centre</b>							
<b>Import of West Bengal Transfer Capability for October 2024</b>							

Issue Date: 26th April 2024			Issue Time: 1600 hrs				Revision No. 0	
<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Approved GNA (MW)</b>	<b>Margin for T-GNA (MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Remarks</b>
1st oct to 31st oct 2024	00-24	3950	450	3500	3516	-16		TRM (Transfer Reliability Margin) is Considering average S/O of the largest Gen Unit
		Limited By LGBR.No other constraints.						



[illegible]

**National Load Despatch Centre**

**Import of West Bengal Transfer Capability for October 2024**

Issue Date: 26th April 2024

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Counterflow on account of surrender of LTA(ISGS)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision	Remarks
1st oct to 31th oct 2024	00-24	1058		78	980	2157	-1177		Generation : 5048 MW Load: 3900 MW
<b>Limiting Constraints</b>			Outage of one 210MW Generator of IBTPS Stage-1						

\*Considering same figure of GNA as declared for import in CTU website

**National Load Despatch Centre**  
**Import of West Bengal Transfer Capability for October 2024**

Issue Date: 26th April 2024

Issue Time: 1600 hrs

Revision No. 0

[illegible]

## Revision No. 0

[illegible]

**National Load Despatch Centre**  
**Import of West Bengal Transfer Capability for October 2024**

Issue Date: 26th April 2024

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin for T GNA (MW)	Changes in TTC w.r.t last revision	Remarks
1st oct to 31th oct 2024	00-24	3001	52	2949				<p>In normal case(not extreme import or export),if 220 KV Waria-DSTps-Parulia(DVC) d/c is in loop,flow of 220 KV DSTPS to Waria d/c may reach 190 MW each,which is a constraint.</p> <p>Consideration: : Hydel generation of 40MW has been considered. DSTPS U#2 generation is not considered since the unit is schedule to be taken under S/D for O/H during Jan'24. All other thermal generators are considered on bar with full generation.</p>
Limiting Constraints		Limited BY LGBR in extreme cases.For normal case,plz see comments.						



**National Load Despatch Centre**  
**Import of West Bengal Transfer Capability for October 2024**

Issue Date: 26th April 2024

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision	Remarks
1st oct to 31th oct 2024	00 to 24 hrs	6175	121	6054	5043.0	1011		
		1.132kv Saharsa New-Sonebarsa						

\_\_\_\_\_