




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

04-Oct-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.15	6.17	24.73	37.29	26.82	4.84	0.00	31.05	56.46	12.49	7.70	99.85	24.13

Average Frequency	49.95	Frequency Variation Index :	0.112	Standard Deviation :	0.092
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.2	8:02:10	Max	50.127	20:00:00
Min	49.68	22:05:50	Min	49.767	22:15:00

