




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

05-Oct-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.53	6.59	25.65	41.15	21.52	3.83	0.74	32.77	55.97	11.26	6.70	98.73	22.35

Average Frequency	49.94	Frequency Variation Index :	0.126	Standard Deviation :	0.096
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.27	18:04:00	Max	50.154	16:15:00
Min	49.56	22:06:20	Min	49.787	12:45:00

