




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

26-Jul-15



<49.2	<49.7	<49.90	<49.97	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	49.90-50.05	49.7-50.2	49.97-50.03	50.05-50.1	>50	>50.03	>50.05	>50.2
0	0.00	2.56	14.56	0.08	2.48	22.70	55.79	15.08	54.04	96.12	26.50	24.58	74.71	58.94	43.40	3.88

Average Frequency	50.04	Frequency Variation Index :	0.080	Standard Deviation :	0.077
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency		
Max	50.33	6:02:20
Min	49.79	19:47:50

15 minute average Frequency		
Max	50.236	6:15:00
Min	49.871	21:15:00

No. of excursion above 50.03 Hz	148
No. of excursion below 49.97 Hz	64
No. of excursion above 50.00 Hz	113
No. of excursion below 50.00 Hz	111

Average time freq remains below 49.97 per excursion	0:03:17	Average time frequency remains above 50.03 per excursion	0:05:44
---	---------	--	---------