




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

27-Oct-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.09	2.71	12.51	36.05	39.11	9.07	0.45	15.31	56.74	27.95	18.48	99.46	22.82

Average Frequency	49.99	Frequency Variation Index :	0.081	Standard Deviation :	0.089
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.26	21:50:50	Max	50.181	22:00:00
Min	49.67	18:09:20	Min	49.804	16:45:00

