

National Load Despatch Centre
Import of Goa Transfer Capability for Mar 2022

Issue Date: 26th Nov 2021

Issue Time: 1800 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|-------------------------------|--|--|---------------------------|--|---|---|--|-----------------|
| 1st Mar 2022 to 31st Mar 2022 | 00-24 | 710 | 15 | 695 | 588 | 107 | | |
| Limiting Constraints | N-1 contingency of 220 kV Mapusa-Ponda-S/C & subsequent 220 kV & 110 kV voltages in Goa system are at the verge of 0.9 pu. | | | | | | | |

National Load Despatch Centre
Import of Goa Transfer Capability for Mar 2022

| Revision No | Date of Revision | Period of Revision | Reason for Revision |
|--------------------|-------------------------|---------------------------|----------------------------|
| | | | |