

**National Load Despatch Centre**  
**Import of Gujarat Transfer Capability for Mar 2022**

Issue Date: 04th Mar 2022

Issue Time: 1100 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
<b>With SSP Generation</b>								
05th Mar 2022 to 31st Mar 2022	00-09	10230	330	9900	8915.316	984.684		<a href="https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf">https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf</a>
05th Mar 2022 to 31st Mar 2022	09-17	9830	330	9500	8915.316	584.684		
05th Mar 2022 to 31st Mar 2022	17-24	10230	330	9900	8915.316	984.684		
<b>Without SSP Generation</b>								
05th Mar 2022 to 31st Mar 2022	00-09	10030	330	9700	8915.316	784.684		<a href="https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf">https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf</a>
05th Mar 2022 to 31st Mar 2022	09-17	9630	330	9300	8915.316	384.684		
05th Mar 2022 to 31st Mar 2022	17-24	10030	330	9700	8915.316	784.684		
<b>Limiting Constraints</b>		1) N-1 contingency of 400 kV D/C Banaskantha – Veloda line. 2) N-1 contingency of 765/400 kV Vadodara ICTs 3) N-1 contingency of 400 kV D/C Kala – Kudus line						

**National Load Despatch Centre**  
**Import of Gujarat Transfer Capability for June 2022**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	04.03.2021	05-31 Mar 2022	Due to change in LTA/MTOA of Gujarat