

**National Load Despatch Centre**  
**Import of Gujarat Transfer Capability for Nov 2021**

Issue Date: 12th Nov 2021

Issue Time: 2100 hrs

Revision No. 2

<b>With SSP Generation</b>								
<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
01st Nov to 30th Nov'21	00-09	10230	330	9900	8863.516	1036		<a href="https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf">https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf</a>
01st Nov to 30th Nov'21	09-17	9830	330	9500	8863.516	636		
01st Nov to 30th Nov'21	17-24	10230	330	9900	8863.516	1036		
<b>Limiting Constraints</b>		1) N-1 contingency of 400 kV D/C Banaskantha – Veloda line. 2) N-1 contingency of 765/400 kV Vadodara ICTS 3) N-1 contingency of 400 kV D/C Kala – Kudus line						

**National Load Despatch Centre**  
**Import of Gujarat Transfer Capability for Nov 2021**

Issue Date: 12th Nov 2021

Issue Time: 2100 hrs

Revision No. 2

<b>Without SSP Generation</b>								
<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
01st Nov to 30th Nov'21	00-09	10030	330	9700	8863.516	836		<a href="https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf">https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf</a>
01st Nov to 30th Nov'21	09-17	9630	330	9300	8863.516	436		
01st Nov to 30th Nov'21	17-24	10030	330	9700	8863.516	836		
<b>Limiting Constraints</b>		1) N-1 contingency of 400 kV D/C Banaskantha – Veloda line. 2) N-1 contingency of 765/400 kV Vadodara ICTs 3) N-1 contingency of 400 kV D/C Kala – Kudus line						