

**National Load Despatch Centre**  
**Import of Haryana Transfer Capability for July 2021**

Issue Date:

Issue Time:

Revision No. 0

| <b>Date</b>                     | <b>Time Period in IST (hrs)</b> | <b>Total Transfer Capability (TTC) (MW)</b>                                       | <b>Reliability Margin (MW)</b> | <b>Available Transfer Capability (ATC) (MW)</b> | <b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)</b> | <b>Margin Available for Short Term Open Access (STOA) (MW)</b> | <b>Changes in TTC w.r.t. Last Revision</b> | <b>Comments</b> |
|---------------------------------|---------------------------------|---|--------------------------------|---|--|--|--|-----------------|
| 1st July 2021 to 31st July 2021 | 00-24                           | 8500  | 600                            | 7900  | 4300   | 3600   |  |                 |
| <b>Limiting Constraints</b>     |                                 | N-1 contingency of 400/220kV ICTs at Deepalpur, Kurukshetra(PG), Sonapat, Panipat |                                |   |  |  |  |                 |

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages