

National Load Despatch Centre
Import of HP Transfer Capability for November 2021

Issue Date: 01-11-2021

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st November 2021 to 30th November 2021	00-24	1200	100	1100	1400	0		https://hpsldc.com/mrm_category/ttc-atc-report/
Limiting Constraints		N-1 contingency of 400/220kV Nallagarh ICTs.						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages