

National Load Despatch Centre
Import of HP Transfer Capability for October 2021

Issue Date: 08-10-2021

Issue Time: 1600

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW) | Margin Available for Short Term Open Access (STOA) (MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---------------------------------------|--------------------------|--|-------------------------|--|---|---|-------------------------------------|---|
| 1st October 2021 to 31st October 2021 | 00-24 | 1200 | 100 | 1100 | 1400 | 0 | | https://hpsidc.com/mrm_category/ttc-atc-report/ |
| Limiting Constraints | | N-1 contingency of 400/220kV Nallagarh ICTs. | | | | | | |

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages