

Rev-1									31.05.2022
State	Date	Time Period (hrs)	TTC (MW)	TRM (MW)	ATC (MW)	Share allocation/ LTA/MTOA (MW)	Margin (ATC-share allocation/LTA/MTOA) (MW)	Limiting Constraint	Remarks
Maharashtra	01 st June -30 th June '22	00-24	10060	300	9760	10563	-803	N-1 of 400 kV Parli-PG-Parli-MH-DC	
#Gujarat	01 st June -30 th June '22	00-09	10230	330	9900	10291	-391	1. N-1 contingency of 400 kV Banaskantha-Veloda-DC 2. N-1 contingency of 400 kV Kudus-Kala-DC	If SSP Generation : 450 MW
		09-17	9830	330	9500	10291	-791		
		17-24	10230	330	9900	10291	-391		
		00-09	10030	330	9700	10291	-591		
		09-17	9630	330	9300	10291	-991		
		17-24	10030	330	9700	10291	-591		
*Madhya Pradesh	01 st June -30 th June '22	00-24	10801	300	10501	10272	229		
Chhattisgarh	01 st June	00-24	2590	50	2540	2859	-319	N-1 contingency of (a)400/220 kV Bhatapara	

	-30 th June '22								ICTs, (b) 400/220 kV NSPCL ICTs, (c) 400/220kV Raigarh-PG ICTs
Goa	01 st June -30 th June '22	00-24	710	15	695	588	107		N-1 contingency of 220 kV Mapusa-Ponda-S/C & subsequent 220 kV & 110 kV voltages in Goa system are at the verge of 0.9 pu.
DD	01 st June -30 th June '22	00-24	620	10	610	339.72	270.28		N-1 contingency of 220 kV Magarwada (PG)- Magarwada (DD) D/C
DNH	01 st June -30 th June '22	00-24	840	15	825	1200.63	-375.63		N-1 contingency of 220 kV Kala-Khadoli D/C
# https://www.sldcguj.com/Operation/TTC-ATC-Gujarat_State_Revised_9500-9900_Web.pdf									
* https://www.sldcmpindia.com/page.php?id=20 (Updated as per SLDC MP declaration)									
Rev:1- Due to change in LTA/MTOA of MP & Maharashtra									