National Load Despatch Centre

Transfer Capability for Import of DD & DNH for December 2015

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|----------------------------------|-----------------------------|--|-----------------------|--|--|--|---|----------|
| 1st Dec 2015 to 31st Dec 2015 | 00-24 | 1200 | 0 | 1200 | LTA and MTOA as per ex-pp schedule | | | |

| Limiting Constraints | (n-1) contingency of 400/220KV 315MVA ICT at VAPI |
|----------------------|---|

National Load Despatch Centre Total Transfer Capability for December 2015

| Revision No | Date of Revision | Period of Revision | Reason for Revision | Corridor Affected |
|----------------|---------------------|--------------------|---------------------|----------------------|
| | | | · | |