

**National Load Despatch Centre**  
**Transfer Capability for Import of DD & DNH for June 2016**

Issue Date: 28/2/2016

Issue Time: 1500 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st June 2016 to 30th June2016	00-24	1200	0	1200	LTA and MTOA as per ex-pp schedule			

<b>Limiting Constraints</b>	(n-1) contingency of 400/220KV 315MVA ICT at VAPI
-----------------------------	---

**National Load Despatch Centre  
Total Transfer Capability for June 2016**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>	<b>Corridor Affected</b>