

**National Load Despatch Centre**  
**Transfer Capability for Import of DNH for February 2021**

Issue Date: 28th October 2020

Issue Time: 1800 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st February 2021 to 28th February 2021	00-24	840	15	825	LTA and MTOA as per ex-pp schedule			

<b>Limiting Constraints</b>	N-1 contingency of 220 kV Kala-Khadoli line will overload the other circuit
-----------------------------	---

**National Load Despatch Centre  
Transfer Capability for Import of DNH for February 2021**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>	<b>Corridor Affected</b>