National Load Despatch Centre Import of DNH Transfer Capability for June 2021

| Issue Date: 27th February 2021 | | | Issue Time: 1700 hrs | | | Revision No. 0 | | |
|------------------------------------|-----------------------------|--|-----------------------|--|--|--|---|--------------------------------|
| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
| 1st June 2021 to 30th June 2021 | 00-24 | 840 | 15 | 825 | 1023 | -198 | | Allocated LTA is more than ATC |
| Limiting Constraints | | N-1 contingency of 220 kV Kala-Khadoli D/C | | | | | | |

National Load Despatch Centre Import of DNH Transfer Capability for June 2021

| Revision | Date of | Period of | Reason for Revision | |
|----------|----------|-----------|----------------------------|--|
| No | Revision | Revision | | |
| | | | | |