

National Load Despatch Centre
Transfer Capability for Import of Maharashtra for December 2020

Issue Date: 28th August 2020

Issue Time: 1800 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2020 to 31st December 2020	00-24	10200	300	9900	7714	2186		

Limiting Constraints	N-1 contingency one ckt. of 400 kV Parli (PG)-Parli (MH)-D/C will lead to overloading of other ckt.
-----------------------------	---

National Load Despatch Centre
Transfer Capability for Import of Maharashtra for December 2020

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected