## **National Load Despatch Centre**

## Import of Punjab Transfer Capability for August 2018

Issue Date: 01/05/2018 Issue Time: 1600 hrs Revision No. 0

| Date                               | Time Period in<br>IST (hrs) | Total<br>Transfer<br>Capability<br>(TTC)   | Reliability<br>Margin | Available<br>Transfer<br>Capability<br>(ATC) | Long Term<br>Access (LTA)/<br>Medium Term<br>Open Access<br>(MTOA) # | Margin<br>Available for<br>Short Term<br>Open Access<br>(STOA) | Changes in TTC<br>w.r.t. Last<br>Revision | Comments |
|------------------------------------|-----------------------------|--|-----------------------|--|--|--|---|----------|
| 1st August 18 to<br>31st August 18 | 00-24                       | 7000   | 600                   | 6400   | 4680   | 1720   |   |          |
| <b>Limiting Constraints</b>        |                             | (N-1) contingency of 500 MVA ICT at Ludhiana (PG), Amritsar (PG) and N-1 contigency of 315 MVA ICT at Makhu will crirically load other ICTs. 2. 220 kV underlying network at Ludhiana and Amritsar |                       |  |  |  |   |          |

## National Load Despatch Centre Import of Punjab Transfer Capability for August 2018

| Revision<br>No | Date of<br>Revision | Period of<br>Revision | Reason for Revision |  |  |
|----------------|---------------------|-----------------------|---------------------|--|--|
|                |                     |                       |                     |  |  |