

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for Aug 2022**

Issue Date: 20 May 2022

Issue Time: 1500 Hrs

Revision No. 1

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st Aug 2022 to 31st Aug 2022	00-08	8200	500	7700	4860	2840	200	Augmentation of 315MVA ICT by 500MVA ICT at Ludhiana(PG)
	08-18	8200	500	7700	4860	2840	500	
	18-24	8200	500	7700	4860	2840	200	
<b>Limiting Constraints</b>		1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana. SPS installed at Rajpura and Nakodar. 2. 220 kV underlying network at Ludhiana and Amritsar 3. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC. 4. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit.						

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for Aug 2022**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	20.05.2022	1st Aug 2022 to 31st Aug 2022	Augmentation of 315MVA ICT by 500MVA ICT at Ludhiana(PG)