

National Load Despatch Centre
Import of Punjab Transfer Capability for December 2023

Issue Date: 28th August 2023

Issue Time: 15:00

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2023 to 31st December 2023	00-08	9500	500	9000	5197	3803		
	08-18	9500	500	9000	5197	3803		
	18-24	9500	500	9000	5197	3803		
Limiting Constraints		<ol style="list-style-type: none"> 1. N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar. 2. Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla, Moga and Patiala ICTs 3. 220 kV underlying network at Jalandhar, Ludhiana and Amritsar 4. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC. 5. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit. 						

National Load Despatch Centre
Import of Punjab Transfer Capability for December 2023

Revision No	Date of Revision	Period of Revision	Reason for Revision