National Load Despatch Centre

Import of Punjab Transfer Capability for February 2016

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st Feb to 29th Feb	00-24	6200	500	5700	4033	1667			
Limiting Constraints		(N-1) contingency of 400/220 kV ICT at Amritsar, Dhuri and 220 kV underlying network at Ludhiana							

National Load Despatch Centre

Revision	Date of	Period of	Reason for Revision	Corridor
No	Revision	Revision		Affected