National Load Despatch Centre Import of Punjab Transfer Capability for Feb'26

Issue Date: -26th February 2025 Issue Time: 15:00 Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	* *	Margin Available for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Comments	
1st Feb'26 to 28th Feb'26	00-24	10600	500	10100	5497	4603			
Limiting Constra	nints	1. N-1 contigency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar. 2.Loading close to N-1 contingency limits of 400/220kV Malerkotla, Moga and Patiala ICTs 3. 220 kV underlying network at Jalandhar, Ludhiana and Amritsar 4. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC. 5. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit.							

Import of Punjab Transfer Capability for Feb'26

Issue Date:	Date of Revision	Period of Revision	Reason for Revision			