

National Load Despatch Centre
Import of Punjab Transfer Capability for Jan 2026

Issue Date: 25-12-2025

Issue Time: 17:00

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Approved GNA (MW) | Margin Available for T-GNA (MW) | Changes in TTC w.r.t. Last Revision | Comments |
|--------------------------------|--------------------------|--|--------------------|-------------------------------------|-------------------|---------------------------------|-------------------------------------|----------|
| 01st Jan 2026 to 31st Jan 2026 | 00-24 | 10300 | 500 | 9800 | 5497 | 4303 | 0 | |
| Limiting Constraints | | 1. N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar. 2. Loading close to N-1 contingency limits of 400/220KV Patran, Malerkotla, Moga and Patiala ICTs 3. 220 kV underlying network at Jalandhar, Ludhiana and Amritsar 4. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC. 5. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit. | | | | | | |

Import of Punjab Transfer Capability for Jan 2026

| Issue Date: 25-12-2025 | Date of Revision | Period of Revision | Reason for Revision |
|------------------------|------------------|--------------------|---------------------|
| | | | |